




# FUEL REPORT

Sample Rating Trend



ISO



Machine Id

## EPA UST 4

Component

### Tank Diesel Fuel

Fluid

### DIESEL FUEL No. 2 (--- GAL)

#### DIAGNOSIS

##### ▲ Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

##### Corrosion

All metal levels are normal indicating no corrosion in the system.

##### ▲ Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

##### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0879220</b>	---	---
Sample Date	Client Info			<b>13 Nov 2023</b>	---	---
Machine Age	hrs	Client Info		<b>0</b>	---	---
Sample Status				<b>ATTENTION</b>	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		<b>0.841</b>	---	---
Fuel Color	text	*Visual Screen		<b>Red</b>	---	---
ASTM Color	scalar	*ASTM D1500		<b>L4.5</b>	---	---
Visc @ 40°C	cSt	ASTM D445	4.1	<b>2.54</b>	---	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		<b>65</b>	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		<b>41</b>	---	---
Sulfur (UVF)	ppm	ASTM D5453		<b>48</b>	---	---

DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		<b>175</b>	---	---
5% Distillation Point	°C	ASTM D86		<b>197</b>	---	---
10% Distill Point	°C	ASTM D86		<b>206</b>	---	---
15% Distillation Point	°C	ASTM D86		<b>214</b>	---	---
20% Distill Point	°C	ASTM D86		<b>221</b>	---	---
30% Distill Point	°C	ASTM D86		<b>234</b>	---	---
40% Distill Point	°C	ASTM D86		<b>248</b>	---	---
50% Distill Point	°C	ASTM D86		<b>261</b>	---	---
60% Distill Point	°C	ASTM D86		<b>275</b>	---	---
70% Distill Point	°C	ASTM D86		<b>290</b>	---	---
80% Distill Point	°C	ASTM D86		<b>307</b>	---	---
85% Distillation Point	°C	ASTM D86		<b>316</b>	---	---
90% Distill Point	°C	ASTM D86		<b>328</b>	---	---
95% Distillation Point	°C	ASTM D86		<b>344</b>	---	---
Final Boiling Point	°C	ASTM D86		<b>351</b>	---	---
Distillation Residue	%	ASTM D86		<b>1.4</b>	---	---
Distillation Loss	%	ASTM D86		<b>0.9</b>	---	---


IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		<b>36.8</b>	---	---
Cetane Index		ASTM D4737	<40.0	<b>48.7</b>	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	---	---
Sodium	ppm	ASTM D5185m	<0.1	<b>3</b>	---	---
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	---	---
Water	%	ASTM D6304	<0.05	<b>0.004</b>	---	---
ppm Water	ppm	ASTM D6304	<500	<b>44.0</b>	---	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---	---
% Biodiesel	%	*In-House	<20.0	<b>1.6</b>	---	---




# FUEL REPORT


## Particle Count




## Particle Trend



## Fuel Distillation Curve



## Water (KF)



## Viscosity @ 40°C



FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 6692	---	---
Particles >6µm	ASTM D7647	>640	▲ 2122	---	---
Particles >14µm	ASTM D7647	>80	▲ 178	---	---
Particles >21µm	ASTM D7647	>20	▲ 55	---	---
Particles >38µm	ASTM D7647	>4	2	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/18/15	---	---

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml WC-Method	>=100000	0	---	---
Yeast	CFU/ml WC-Method	>=100000	0	---	---
Mold	Colonies WC-Method	MODER	---	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185m	<0.1	0	---	---
Nickel	ppm ASTM D5185m	<0.1	0	---	---
Lead	ppm ASTM D5185m	<0.1	0	---	---
Vanadium	ppm ASTM D5185m	<0.1	0	---	---
Iron	ppm ASTM D5185m	<0.1	0	---	---
Calcium	ppm ASTM D5185m	<0.1	2	---	---
Magnesium	ppm ASTM D5185m	<0.1	0	---	---
Phosphorus	ppm ASTM D5185m	<0.1	3	---	---
Zinc	ppm ASTM D5185m	<0.1	0	---	---

## SAMPLE IMAGES

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0879220 **Received** : 16 Nov 2023  
**Lab Number** : 06010444 **Diagnosed** : 10 Dec 2023  
**Unique Number** : 10749588 **Diagnostician** : Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: Bacteria, Screen )

**Red Star Oil Co.**  
 802 Purser Drive  
 Raleigh, NC  
 US 27603  
 Contact: DANNY DURHAM  
 ddurham@redstaroil.com  
 T:  
 F: (919)779-8871

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)