




PROBLEM SUMMARY

Area
COLD MILL/CM-3STD-2N
 Machine Id
S2 EAST MOTOR BEARING 3ST2_S2 East Motor Bearing
 Component
Bearing
 Fluid
ROYAL PURPLE SYNFILM GT 68 (50 GAL)

Sample Rating Trend




WEAR




COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	SEVERE	SEVERE
Tin	ppm	ASTM D5185m >20	▲ 32	● 485	● 523
Particles >4µm		ASTM D7647 >10000	▲ 77821	2871	▲ 268167
Particles >6µm		ASTM D7647 >2500	▲ 3956	1564	▲ 129399
Oil Cleanliness		ISO 4406 (c) >20/18/14	▲ 23/19/13	▲ 19/18/15	▲ 25/24/13

Customer Id: CONMUSAL
 Sample No.: KFS0003647
 Lab Number: 06010743
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

27 Jul 2023 Diag: Jonathan Hester

WEAR



We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Bearing and/or bushing wear is indicated. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



12 Apr 2023 Diag: Doug Bogart

WEAR



We recommend that you drain the oil from the component if this has not already been done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Bearing and/or bushing wear is indicated. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

view report



10 Jan 2023 Diag: Doug Bogart

WEAR



We recommend you service the filters on this component if applicable. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Bearing and/or bushing wear is indicated. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
COLD MILL/CM-3STD-2N
 Machine Id
S2 EAST MOTOR BEARING 3ST2_S2 East Motor Bearing
 Component
Bearing
 Fluid
ROYAL PURPLE SYNFILM GT 68 (50 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The tin level has decreased, but is still abnormal. All other component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0003647	KFS0003686	KFS0003085
Sample Date	Client Info	15 Nov 2023	27 Jul 2023	12 Apr 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	SEVERE	SEVERE

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >20	1	2	<1
Chromium	ppm ASTM D5185m >20	<1	0	0
Nickel	ppm ASTM D5185m >20	0	0	0
Titanium	ppm ASTM D5185m	<1	0	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >20	<1	<1	0
Lead	ppm ASTM D5185m >20	0	2	<1
Copper	ppm ASTM D5185m >20	2	▲ 23	▲ 22
Tin	ppm ASTM D5185m >20	▲ 32	◆ 485	◆ 523
Vanadium	ppm ASTM D5185m	<1	<1	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	<1	0	<1
Magnesium	ppm ASTM D5185m 90	0	77	84
Calcium	ppm ASTM D5185m	0	0	<1
Phosphorus	ppm ASTM D5185m	30	0	<1
Zinc	ppm ASTM D5185m	0	0	0
Sulfur	ppm ASTM D5185m	2156	21313	21734

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >15	7	3	2
Sodium	ppm ASTM D5185m	2	1	<1
Potassium	ppm ASTM D5185m >20	<1	<1	<1


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 77821	2871	▲ 268167
Particles >6µm	ASTM D7647 >2500	▲ 3956	1564	▲ 129399
Particles >14µm	ASTM D7647 >160	79	▲ 266	45
Particles >21µm	ASTM D7647 >40	20	▲ 90	6
Particles >38µm	ASTM D7647 >10	1	▲ 14	1
Particles >71µm	ASTM D7647 >3	0	1	0
Oil Cleanliness	ISO 4406 (c) >20/18/14	▲ 23/19/13	▲ 19/18/15	▲ 25/24/13


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	0.28	0.38	0.36


▲ Particle Trend




▲ Particle Trend




▲ Non-ferrous Metals



Acid Number




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	68	69.3	67.0

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KFS0003647 **Received** : 17 Nov 2023
Lab Number : 06010743 **Diagnosed** : 20 Nov 2023
Unique Number : 10749887 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONSTELLIUM

4805 SECOND STREET
MUSCLE SHOALS, AL
US 35661

Contact: Josh Edwards
joshua.edwards@constellium.com

T: (256)386-6613

F: