


# PROBLEM SUMMARY

Sample Rating Trend




ISO



Area  
**TM 6**  
Machine Id  
**SOUTH EXHAUSTER**  
Component  
**Compressor**  
Fluid  
**REFRIG COMP OIL ISO 32 (60 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	▲ 11428	3015	4375
Particles >6µm	ASTM D7647	>2500	▲ 3793	1021	1123
Particles >14µm	ASTM D7647	>320	▲ 415	120	106
Particles >21µm	ASTM D7647	>80	▲ 121	35	29
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 21/19/16	19/17/14	19/17/14

Customer Id: KIMMOBTM6  
Sample No.: RP0030565  
Lab Number: 06010761  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

## HISTORICAL DIAGNOSIS

### 09 Aug 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 24 May 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Feb 2023 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**TM 6**  
 Machine Id  
**SOUTH EXHAUSTER**  
 Component  
**Compressor**  
 Fluid  
**REFRIG COMP OIL ISO 32 (60 GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>RP0030565</b>	RP0034419	RP0023568
Sample Date	Client Info	<b>17 Nov 2023</b>	09 Aug 2023	24 May 2023
Machine Age	wks Client Info	<b>0</b>	0	0
Oil Age	wks Client Info	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	<b>11</b>	12	16
Iron	ppm ASTM D5185m >50	<b>0</b>	<1	1
Chromium	ppm ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm ASTM D5185m	<b>0</b>	0	0
Titanium	ppm ASTM D5185m	<b>0</b>	0	0
Silver	ppm ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm ASTM D5185m >25	<b>0</b>	<1	<1
Lead	ppm ASTM D5185m >25	<b>0</b>	0	0
Copper	ppm ASTM D5185m >50	<b>0</b>	<1	0
Tin	ppm ASTM D5185m >15	<b>0</b>	0	0
Vanadium	ppm ASTM D5185m	<b>0</b>	<1	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 5	<b>0</b>	0	0
Barium	ppm ASTM D5185m 5	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m 5	<b>0</b>	0	0
Manganese	ppm ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm ASTM D5185m 5	<b>0</b>	0	0
Calcium	ppm ASTM D5185m 12	<b>0</b>	0	<1
Phosphorus	ppm ASTM D5185m 12	<b>78</b>	80	74
Zinc	ppm ASTM D5185m 12	<b>33</b>	0	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	<b>&lt;1</b>	<1	2
Sodium	ppm ASTM D5185m	<b>&lt;1</b>	0	1
Potassium	ppm ASTM D5185m >20	<b>0</b>	<1	0
Water	% ASTM D6304 >0.1	<b>0.004</b>	0.00	0.007
ppm Water	ppm ASTM D6304 >1000	<b>46.7</b>	0.00	71.4

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>▲ 11428</b>	3015	4375
Particles >6µm	ASTM D7647 >2500	<b>▲ 3793</b>	1021	1123
Particles >14µm	ASTM D7647 >320	<b>▲ 415</b>	120	106
Particles >21µm	ASTM D7647 >80	<b>▲ 121</b>	35	29
Particles >38µm	ASTM D7647 >20	<b>6</b>	2	2
Particles >71µm	ASTM D7647 >4	<b>1</b>	0	1
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>▲ 21/19/16</b>	19/17/14	19/17/14

## FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.10	<b>0.14</b>	0.16	0.17

# OIL ANALYSIS REPORT


### ▲ Particle Trend




### Water (KF)




### PQ



### Water (KF)



### Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	32	32.3	32.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




### GRAPHS


#### Ferrous Alloys




#### Non-ferrous Metals




#### Viscosity @ 40°C



#### ▲ Particle Count



#### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0030565 **Received** : 17 Nov 2023  
**Lab Number** : 06010761 **Diagnosed** : 20 Nov 2023  
**Unique Number** : 10749905 **Diagnostician** : Don Baldrige

**Kimberly-Clark - Mobile - TM 6**  
 200 BAYBRIDGE RD  
 MOBILE, AL  
 US 36610

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: MORGAN RUSSELL  
 Morgan.Russell@kcc.com

T:  
 F: (251)452-6335