


PROBLEM SUMMARY

Sample Rating Trend




WATER



Area
TM 6 [NOT MARKED DRY END]
 Machine Id
MAIN LUBE TANK DRY END
 Component
Gearbox
 Fluid
NOT GIVEN (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water (KF)



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	NORMAL
Water	%	ASTM D6304	>0.2	▲ 0.256	● 1.26	0.031
ppm Water	ppm	ASTM D6304	>2000	▲ 2560	● 12600	313.4

Customer Id: KIMMOBTM6
 Sample No.: RP0030561
 Lab Number: 06010763
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

16 Nov 2023 Diag: Don Baldrige

WATER



We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. All component wear rates are normal. There is a high concentration of water present in the oil. Excessive free water present. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

view report



09 Aug 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



24 May 2023 Diag: Don Baldrige

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
TM 6 [NOT MARKED DRY END]
 Machine Id
MAIN LUBE TANK DRY END
 Component
Gearbox
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0030561	RP0030563	RP0034430
Sample Date	Client Info	17 Nov 2023	16 Nov 2023	09 Aug 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	SEVERE	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	14	25	10	
Iron	ppm	ASTM D5185m >200	9	5	11
Chromium	ppm	ASTM D5185m >15	0	<1	0
Nickel	ppm	ASTM D5185m >15	0	0	0
Titanium	ppm	ASTM D5185m	0	<1	0
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >25	0	<1	<1
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	0	3	2
Tin	ppm	ASTM D5185m >25	0	<1	0
Vanadium	ppm	ASTM D5185m	0	<1	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	<1
Calcium	ppm	ASTM D5185m	116	<1	36
Phosphorus	ppm	ASTM D5185m	950	415	500
Zinc	ppm	ASTM D5185m	1289	626	696

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	7	3	2
Sodium	ppm	ASTM D5185m	2	2	<1
Potassium	ppm	ASTM D5185m >20	0	2	<1
Water	%	ASTM D6304 >0.2	▲ 0.256	1.26	0.031
ppm Water	ppm	ASTM D6304 >2000	▲ 2560	12600	313.4






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	1150	---	10030
Particles >6µm	ASTM D7647 >5000	626	---	1778
Particles >14µm	ASTM D7647 >640	107	---	43
Particles >21µm	ASTM D7647 >160	36	---	9
Particles >38µm	ASTM D7647 >40	6	---	1
Particles >71µm	ASTM D7647 >10	1	---	0
Oil Cleanliness	ISO 4406 (c) >21/19/16	17/16/14	---	21/18/13

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	1.17	0.62	0.54

OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2%
Free Water	scalar	*Visual		NEG	>10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	214	220	207

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0030561 **Received** : 17 Nov 2023
Lab Number : 06010763 **Diagnosed** : 29 Nov 2023
Unique Number : 10749907 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: PQ, PrtCount)

Kimberly-Clark - Mobile - TM 6
 200 BAYBRIDGE RD
 MOBILE, AL
 US 36610
 Contact: MORGAN RUSSELL
 Morgan.Russell@kcc.com
 T:
 F: (251)452-6335

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)