




# PROBLEM SUMMARY

Sample Rating Trend



ISO




Machine Id  
**7424093 (S/N 1090)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	ATTENTION
Particles >14µm	ASTM D7647	>80	▲ <b>92</b>	42	▲ 109
Particles >21µm	ASTM D7647	>20	▲ <b>23</b>	7	▲ 35
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>19/17/14</b>	17/16/13	▲ 18/14

Customer Id: MICANN  
Sample No.: KC111231  
Lab Number: 06010767  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 30 Dec 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 21 Feb 2022 Diag: Angela Borella

ISO




The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**7424093 (S/N 1090)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

### DIAGNOSIS

#### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a moderate amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

### SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC111231</b>	KC105752	KC97498
Sample Date	Client Info	<b>29 Sep 2023</b>	30 Dec 2022	21 Feb 2022
Machine Age	hrs	<b>11492</b>	2246	6042
Oil Age	hrs	<b>11492</b>	5199	2953
Oil Changed	Client Info	<b>Not Chngd</b>	Changed	Not Chngd
Sample Status		<b>ATTENTION</b>	NORMAL	ATTENTION

### WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<b>0</b>	0	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >50	<b>7</b>	23	7
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	2
Barium	ppm	ASTM D5185m 90	<b>15</b>	0	<1
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m 90	<b>38</b>	9	50
Calcium	ppm	ASTM D5185m 2	<b>&lt;1</b>	0	<1
Phosphorus	ppm	ASTM D5185m	<b>4</b>	4	5
Zinc	ppm	ASTM D5185m	<b>19</b>	4	0

### CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<b>0</b>	0	5
Sodium	ppm	ASTM D5185m	<b>7</b>	2	17
Potassium	ppm	ASTM D5185m >20	<b>2</b>	2	4
Water	%	ASTM D6304 >0.05	<b>0.018</b>	0.004	0.008
ppm Water	ppm	ASTM D6304 >500	<b>184.7</b>	43.7	87.2






### FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>4397</b>	986	11136
Particles >6µm	ASTM D7647 >1300	<b>1182</b>	402	▲ 1872
Particles >14µm	ASTM D7647 >80	▲ <b>92</b>	42	▲ 109
Particles >21µm	ASTM D7647 >20	▲ <b>23</b>	7	▲ 35
Particles >38µm	ASTM D7647 >4	<b>1</b>	1	2
Particles >71µm	ASTM D7647 >3	<b>0</b>	1	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ <b>19/17/14</b>	17/16/13	▲ 18/14

### FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.29</b>	0.23	0.31

# OIL ANALYSIS REPORT






PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

PARAMETER	method	limit/base	current	history1	history2
FLUID PROPERTIES					
Visc @ 40°C	cSt	ASTM D445 46	44.1	44.4	47.9

PARAMETER	method	limit/base	current	history1	history2
SAMPLE IMAGES					
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC111231 **Received** : 17 Nov 2023  
**Lab Number** : 06010767 **Diagnosed** : 20 Nov 2023  
**Unique Number** : 10749911 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**MICHIGAN INNOVATION HQ**  
 600 S WAGNER RD  
 ANN ARBOR, MI  
 US 48103  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: