




PROBLEM SUMMARY


Sample Rating Trend



Machine Id
KAESER ASD 25T 5740630 (S/N 1087)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | | ATTENTION | ABNORMAL | ABNORMAL |
|-----------------|--------------|--------|-----------|----------|----------|
| Particles >6µm | ASTM D7647 | >1300 | ▲ 1760 | --- | ▲ 3343 |
| Particles >14µm | ASTM D7647 | >80 | ▲ 85 | --- | ▲ 371 |
| Oil Cleanliness | ISO 4406 (c) | >17/13 | ▲ 18/14 | --- | ▲ 19/16 |

Customer Id: PRENOV
 Sample No.: KC111932
 Lab Number: 06010771
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---------------|--------|------|---------|---|
| Change Fluid | --- | --- | ? | Oil and filter change at the time of sampling has been noted. |
| Change Filter | --- | --- | ? | Oil and filter change at the time of sampling has been noted. |

HISTORICAL DIAGNOSIS

22 Sep 2021 Diag: Don Baldrige

VIS DEBRIS



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



07 Dec 2020 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



12 Mar 2020 Diag: Jonathan Hester

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
KAESER ASD 25T 5740630 (S/N 1087)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | KC111932 | KC99831 | KC93658 |
| Sample Date | Client Info | | 12 Oct 2023 | 22 Sep 2021 | 07 Dec 2020 |
| Machine Age | hrs | Client Info | 37617 | 26794 | 22769 |
| Oil Age | hrs | Client Info | 37617 | 4025 | 5000 |
| Oil Changed | Client Info | | Changed | Changed | Changed |
| Sample Status | | | ATTENTION | ABNORMAL | ABNORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|------------|----------|----------|
| Iron | ppm | ASTM D5185m >50 | 0 | <1 | <1 |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >3 | 0 | 0 | <1 |
| Titanium | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | 0 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m >10 | 0 | 2 | <1 |
| Lead | ppm | ASTM D5185m >10 | 0 | <1 | 0 |
| Copper | ppm | ASTM D5185m >50 | 12 | 7 | 7 |
| Tin | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|----------------|-----------|----------|----------|
| Boron | ppm | ASTM D5185m | 0 | <1 | 0 |
| Barium | ppm | ASTM D5185m 90 | 0 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | <1 |
| Manganese | ppm | ASTM D5185m | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 90 | 12 | 29 | 31 |
| Calcium | ppm | ASTM D5185m 2 | 0 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | 0 | 3 | 3 |
| Zinc | ppm | ASTM D5185m | 41 | 47 | 51 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | <1 | <1 | 1 |
| Sodium | ppm | ASTM D5185m | 10 | 6 | 11 |
| Potassium | ppm | ASTM D5185m >20 | 1 | <1 | 0 |
| Water | % | ASTM D6304 >0.05 | 0.008 | 0.017 | 0.011 |
| ppm Water | ppm | ASTM D6304 >500 | 89.3 | 172.6 | 115.4 |

FLUID CLEANLINESS


| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|----------------|----------|----------|
| Particles >4µm | ASTM D7647 | | 8783 | --- | 8154 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 1760 | --- | ▲ 3343 |
| Particles >14µm | ASTM D7647 | >80 | ▲ 85 | --- | ▲ 371 |
| Particles >21µm | ASTM D7647 | >20 | 19 | --- | ▲ 95 |
| Particles >38µm | ASTM D7647 | >4 | 1 | --- | 3 |
| Particles >71µm | ASTM D7647 | >3 | 0 | --- | 0 |
| Oil Cleanliness | ISO 4406 (c) | >17/13 | ▲ 18/14 | --- | ▲ 19/16 |

FLUID DEGRADATION


| | method | limit/base | current | history1 | history2 |
|------------------|----------|----------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 0.4 | 0.33 | 0.348 | 0.363 |

OIL ANALYSIS REPORT


▲ Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C




| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | ▲ MODER |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46 | 44.3 | 44.5 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC111932 **Received** : 17 Nov 2023
Lab Number : 06010771 **Diagnosed** : 20 Nov 2023
Unique Number : 10749915 **Diagnostician** : Don Baldrige
Test Package : IND 2

PREZIO HEALTH
 30275 HUDSON DR
 NOVI, MI
 US 48377
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: