




# PROBLEM SUMMARY

Sample Rating Trend



**WATER**



Machine Id  
**KAESER ASD 30 5295588 (S/N 1154)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

No relevant graphs to display

## RECOMMENDATION

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ATTENTION
Free Water	scalar	*Visual	▲ <b>&gt;10%</b>	▲ >10%	NEG

**Customer Id:** SHAROM  
**Sample No.:** KCPA005820  
**Lab Number:** 06010787  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### WATER



#### 16 Jul 2021 Diag: Doug Bogart

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. Please note that this is a corrected copy for laboratory data updates. The copper level is abnormal. All other component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. Free water present. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### ISO



#### 15 Mar 2021 Diag: Don Baldrige

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### ISO



#### 23 Dec 2019 Diag: Doug Bogart


No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Machine Id  
**KAESER ASD 30 5295588 (S/N 1154)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

Excessive free water present.

### Fluid Condition

The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA005820</b>	KCP32041	KCP28186
Sample Date	Client Info	<b>13 Oct 2023</b>	16 Jul 2021	15 Mar 2021
Machine Age	hrs	Client Info	52625	41662
Oil Age	hrs	Client Info	11590	6000
Oil Changed	Client Info	<b>N/A</b>	Not Changd	Not Changd
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ATTENTION

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	<1
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	<1
Copper	ppm	ASTM D5185m >50	<b>11</b>	7
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0
Barium	ppm	ASTM D5185m 90	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1
Magnesium	ppm	ASTM D5185m 90	<b>16</b>	31
Calcium	ppm	ASTM D5185m 2	<b>0</b>	0
Phosphorus	ppm	ASTM D5185m	<b>0</b>	5
Zinc	ppm	ASTM D5185m	<b>135</b>	43
Sulfur	ppm	ASTM D5185m	<b>18091</b>	16748

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	<1
Sodium	ppm	ASTM D5185m	<b>4</b>	2
Potassium	ppm	ASTM D5185m >20	<b>0</b>	1
Water	%	ASTM D6304 >0.05	<b>0.042</b>	▲ 0.748
ppm Water	ppm	ASTM D6304 >500	<b>420</b>	▲ 7480




## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>---</b>	---	4420
Particles >6µm	ASTM D7647 >1300	<b>---</b>	---	996
Particles >14µm	ASTM D7647 >80	<b>---</b>	---	▲ 89
Particles >21µm	ASTM D7647 >20	<b>---</b>	---	▲ 26
Particles >38µm	ASTM D7647 >4	<b>---</b>	---	0
Particles >71µm	ASTM D7647 >3	<b>---</b>	---	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	<b>---</b>	---	▲ 17/14

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.35</b>	0.359

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		▲ >10%	▲ >10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.1	44.3	44.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA005820 **Received** : 17 Nov 2023  
**Lab Number** : 06010787 **Diagnosed** : 20 Nov 2023  
**Unique Number** : 10749931 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**SHARP TOOLING SOLUTIONS**  
 70745 POWELL RD  
 ROMEO, MI  
 US 48065  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)