



## **PROBLEM SUMMARY**



### Machine Id 3178128 (S/N 1022) Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ATTENTION	ABNORMAL		
Water	%	ASTM D6304	>0.05	<b>0.264</b>	0.004	0.007		
ppm Water	ppm	ASTM D6304	>500	🔺 2640	46.8	70.4		

Customer Id: BARMAD Sample No.: KCPA005154 Lab Number: 06010810 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>


### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 09 Dec 2021 Diag: Don Baldridge

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





Report Id: BARMAD [WUSCAR] 06010810 (Generated: 11/29/2023 15:48:12) Rev: 1



### **OIL ANALYSIS REPORT**

# Sample Rating Trend WATER

Machine Id 3178128 (S/N 1022) Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

### DIAGNOSIS

### Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	<b>MATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA005154	KCP36853	KCP21528
Sample Date		Client Info		31 Oct 2023	09 Dec 2021	26 Nov 2019
Machine Age	hrs	Client Info		50499	44817	39002
Oil Age	hrs	Client Info		0	6000	5000
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	7	16	11
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m			0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	<1	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	31	8	10
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		14	69	160
Zinc	ppm	ASTM D5185m		20	38	44
Sulfur	ppm	ASTM D5185m		16804	13333	9908
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		8	3	6
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.05	<u> </u>	0.004	0.007
ppm Water	ppm	ASTM D6304	>500	<b>2640</b>	46.8	70.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		359	3864	19715
Particles >6µm		ASTM D7647	>1300	71	1108	▲ 6683
Particles >14µm		ASTM D7647	>80	2	<b>1</b> 03	666
Particles >21µm		ASTM D7647	>20	0	<b>1</b> 21	<b>2</b> 67
Particles >38µm		ASTM D7647	>4	0	3	<b>A</b> 31
Particles >71µm		ASTM D7647	>3	0	0	<b>4</b>
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/13/9	▲ 17/14	<b>2</b> 0/17
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.31	0.236


Report Id: BARMAD [WUSCAR] 06010810 (Generated: 11/29/2023 15:48:13) Rev: 1


Contact/Location: Service Manager - BARMAD




Built for a lifetime.

## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	LIGHT
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.1	44.0	44.1
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color						



Bottom



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - BARMAD

F: