




PROBLEM SUMMARY

Sample Rating Trend




WATER



Machine Id
KAESER SX 7.5 8382249 (S/N 11866)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Water (KF)



RECOMMENDATION

We were unable to perform a particle count on this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

| Sample Status | | | | ABNORMAL | --- | ABNORMAL |
|------------------|--------|------------|-------|-----------------|---------|----------|
| Water | % | ASTM D6304 | >0.05 | ▲ 0.164 | ● 4.16 | 0.003 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 1640 | ● 41600 | 30.2 |
| Emulsified Water | scalar | *Visual | >0.05 | ▲ 0.2% | ● 0.2% | NEG |

Customer Id: EVECLYKC
Sample No.: KC124846
Lab Number: 06010828
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|--------|--------|------|---------|---|
| Alert | --- | --- | ? | We were unable to perform a particle count due to a high concentration of particles present in this sample. |

HISTORICAL DIAGNOSIS

23 Aug 2023 Diag:

UNKNOWN



view report



21 Apr 2023 Diag: Doug Bogart

VIS DEBRIS



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER SX 7.5 8382249 (S/N 11866)

Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

We were unable to perform a particle count on this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KC124846 | KC06005634 | KC111742 |
| Sample Date | Client Info | | | 07 Nov 2023 | 23 Aug 2023 | 21 Apr 2023 |
| Machine Age | hrs | Client Info | | 9330 | 7766 | 4841 |
| Oil Age | hrs | Client Info | | 0 | 0 | 4841 |
| Oil Changed | Client Info | | | N/A | N/A | Changed |
| Sample Status | | | | ABNORMAL | --- | ABNORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|----------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 0 | 3 | 0 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 1 | 0 |
| Copper | ppm | ASTM D5185m | >50 | 6 | ▲ 61 | 16 |
| Tin | ppm | ASTM D5185m | >10 | 0 | <1 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |




| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|-----------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | 90 | 15 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 90 | 22 | 0 | 1 |
| Calcium | ppm | ASTM D5185m | 2 | 0 | 0 | 2 |
| Phosphorus | ppm | ASTM D5185m | | 0 | 0 | 3 |
| Zinc | ppm | ASTM D5185m | | 5 | 0 | 0 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|----------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | <1 | 16 | 2 |
| Sodium | ppm | ASTM D5185m | | 7 | 1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | <1 | 2 | 0 |
| Water | % | ASTM D6304 | >0.05 | ▲ 0.164 | ● 4.16 | 0.003 |
| ppm Water | ppm | ASTM D6304 | >500 | ▲ 1640 | ● 41600 | 30.2 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.30 | 0.28 | 0.40 |


| VISUAL | | method | limit/base | current | history1 | history2 |
|------------------|--------|---------|------------|---------------|----------|----------|
| White Metal | scalar | *Visual | NONE | HEAVY | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | ▲ MODER |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | ▲ 0.2% | ● 0.2% | NEG |
| Free Water | scalar | *Visual | | NEG | ● | NEG |

OIL ANALYSIS REPORT




| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|--------------|-------------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 46 | 43.6 | 44.7 | 44.2 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|




GRAPHS


Ferrous Alloys




Non-ferrous Metals



Viscosity @ 40°C



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC124846 **Received** : 17 Nov 2023
Lab Number : **06010828** **Diagnosed** : 20 Nov 2023
Unique Number : 10749972 **Diagnostician** : Don Baldrige
Test Package : IND 2

EVERGREEN PLASTICS
 202 WATER TOWER DR
 CLYDE, OH
 US 43410
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: