PROBLEM SUMMARY

Sample Rating Trend



ISO

Machine Id
KAESER SK 15 4353808 (S/N 1216)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	ABNORMAL
Particles >6µm		ASTM D7647	>1300	▲ **15983**	---	▲ 7735
Particles >14µm		ASTM D7647	>80	▲ **1399**	---	▲ 149
Particles >21µm		ASTM D7647	>20	▲ **285**	---	15
Particles >38µm		ASTM D7647	>4	▲ **6**	---	1
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ **22/21/18**	---	▲ 20/14

Customer Id: SHAROM
Sample No.: KCPA006000
Lab Number: 06010835
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldridge +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

16 Jul 2021 Diag: Doug Bogart

WATER

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. Please note that this is a corrected copy for laboratory data updates.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a moderate amount of visible silt present in the sample. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

view report

15 Mar 2021 Diag: Don Baldridge

ISO

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

15 Jun 2020 Diag: Doug Bogart

ISO

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
KAESER SK 15 4353808 (S/N 1216)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation
No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of particulates present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KCPA006000**	KCP32025	KCP28116
Sample Date		Client Info		**13 Oct 2023**	16 Jul 2021	15 Mar 2021
Machine Age	hrs	Client Info		**17605**	17295	15228
Oil Age	hrs	Client Info		**0**	6000	5684
Oil Changed		Client Info		**N/A**	Changed	Changed
Sample Status				**ABNORMAL**	SEVERE	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**0**	<1	<1
Chromium	ppm	ASTM D5185m	>10	**0**	0	0
Nickel	ppm	ASTM D5185m	>3	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**0**	0	0
Silver	ppm	ASTM D5185m	>2	**0**	0	0
Aluminum	ppm	ASTM D5185m	>10	**0**	0	0
Lead	ppm	ASTM D5185m	>10	**0**	<1	0
Copper	ppm	ASTM D5185m	>50	**4**	2	6
Tin	ppm	ASTM D5185m	>10	**0**	0	0
Antimony	ppm	ASTM D5185m		**---**	0	0
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	13
Barium	ppm	ASTM D5185m	90	**6**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	<1	<1
Magnesium	ppm	ASTM D5185m	90	**67**	16	24
Calcium	ppm	ASTM D5185m	2	**0**	<1	0
Phosphorus	ppm	ASTM D5185m		**0**	▲ 77	4
Zinc	ppm	ASTM D5185m		**11**	▲ 33	14
Sulfur	ppm	ASTM D5185m		**18117**	▲ 7909	16167

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**<1**	<1	<1
Sodium	ppm	ASTM D5185m		**13**	4	3
Potassium	ppm	ASTM D5185m	>20	**1**	1	0
Water	%	ASTM D6304	>0.05	**0.022**	⬢ 1.26	0.018
ppm Water	ppm	ASTM D6304	>500	**227.2**	⬢ 12600	186.6

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**38923**	---	19100
Particles >6µm		ASTM D7647	>1300	▲ **15983**	---	▲ 7735
Particles >14µm		ASTM D7647	>80	▲ **1399**	---	▲ 149
Particles >21µm		ASTM D7647	>20	▲ **285**	---	15
Particles >38µm		ASTM D7647	>4	▲ **6**	---	1
Particles >71µm		ASTM D7647	>3	**0**	---	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ **22/21/18**	---	▲ 20/14

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	**0.35**	0.285	0.359

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	▲ MODER	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**NEG**	⬢ 0.2%	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	**43.9**	43.6	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006000 **Received** : 17 Nov 2023
Lab Number : 06010835 **Diagnosed** : 20 Nov 2023
Unique Number : 10749979 **Diagnostician** : Don Baldridge
Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SHARP TOOLING SOLUTIONS
70745 POWELL RD
ROMEO, MI
US 48065
Contact: SERVICE MANAGER
T:
F: