




# PROBLEM SUMMARY


Sample Rating Trend



Machine Id  
**KAESER AS 25T 5245033 (S/N 1118)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	ATTENTION	ABNORMAL
Particles >6µm	ASTM D7647	>1300	▲ 1511	1141	▲ 12612
Particles >14µm	ASTM D7647	>80	▲ 114	▲ 111	▲ 1714
Particles >21µm	ASTM D7647	>20	▲ 29	▲ 39	▲ 527
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 20/18/14	▲ 17/14	▲ 21/18

Customer Id: STEMAD  
 Sample No.: KC06010855  
 Lab Number: 06010855  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 19 Feb 2020 Diag: Don Baldrige

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 06 Nov 2018 Diag: Jonathan Hester

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 20 Oct 2016 Diag: Jonathan Hester

WATER



We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition. Please note that this is a corrected copy for diagnostic comment updates. All component wear rates are normal. There is a high amount of particulates present in the oil. Free water present. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**KAESER AS 25T 5245033 (S/N 1118)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KC06010855</b>	KC78003	KC81133
Sample Date	Client Info		<b>24 Aug 2023</b>	19 Feb 2020	06 Nov 2018
Machine Age	hrs	Client Info	<b>5695</b>	4120	307
Oil Age	hrs	Client Info	<b>0</b>	3000	307
Oil Changed	Client Info		<b>N/A</b>	Changed	Changed
Sample Status			<b>ATTENTION</b>	ATTENTION	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m >50	<b>5</b>	6	1
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Antimony	ppm	ASTM D5185m	<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 90	<b>4</b>	2	12
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m 90	<b>47</b>	28	56
Calcium	ppm	ASTM D5185m 2	<b>0</b>	<1	2
Phosphorus	ppm	ASTM D5185m	<b>0</b>	1	1
Zinc	ppm	ASTM D5185m	<b>19</b>	50	10

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	<1	<1
Sodium	ppm	ASTM D5185m	<b>12</b>	13	15
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	1	2
Water	%	ASTM D6304 >0.05	<b>0.017</b>	0.009	0.014
ppm Water	ppm	ASTM D6304 >500	<b>179.6</b>	90.9	140






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>5256</b>	3630	37912
Particles >6µm	ASTM D7647	>1300	<b>▲ 1511</b>	1141	▲ 12612
Particles >14µm	ASTM D7647	>80	<b>▲ 114</b>	▲ 111	▲ 1714
Particles >21µm	ASTM D7647	>20	<b>▲ 29</b>	▲ 39	▲ 527
Particles >38µm	ASTM D7647	>4	<b>1</b>	3	▲ 24
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c)	>--/17/13	<b>▲ 20/18/14</b>	▲ 17/14	▲ 21/18

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.35</b>	0.400	0.339

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.2	44.4	43.82

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC06010855 **Received** : 17 Nov 2023  
**Lab Number** : 06010855 **Diagnosed** : 20 Nov 2023  
**Unique Number** : 10749999 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**STEC USA INC**  
 31831 SHERMAN AVE  
 MADISON HEIGHTS, NY  
 US 48071  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: