


PROBLEM SUMMARY


HIGH PRESSURE PUMP SKINNER 16


Pump Fluid

NOT GIVEN (--- GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

We advise that you follow the water drain-off procedure for this component and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

PROBLEMATIC TEST RESULTS Sample Status SEVERE ABNORMAL Aluminum ppm ASTM D5185m >7 A 17 0 Water % ASTM D6304 > 1 2 12 0.005

Water	%	ASTM D6304	>.1	e 2.12	0.005	
ppm Water	ppm	ASTM D6304	>1000	e 21200	50.4	
Emulsified Water	scalar	*Visual	>.1	0.2%	NEG	
Free Water	scalar	*Visual		a >10%	NEG	

Customer Id: TYSWAV Sample No.: USP0003729 Lab Number: 06010877 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u> ----

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			

HISTORICAL DIAGNOSIS



02 Nov 2023 Diag: Doug Bogart

Resample at the next service interval to monitor. Please specify the brand and viscosity of the oil on your next sample. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

WATER

X

HIGH PRESSURE PUMP SKINNER 16

Pump Fluid NOT GIVEN (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

A Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

Excessive free water present. There is a high concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003729	USP242313	
Sample Date		Client Info		13 Nov 2023	02 Nov 2023	
Machine Age	hrs	Client Info		0	021100/2023	
•		Client Info		0	0	
Oil Age	hrs			U N/A	0 N/A	
Oil Changed		Client Info				
Sample Status				SEVERE	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	36	2	
Chromium	ppm	ASTM D5185m	>5	3	0	
Nickel	ppm	ASTM D5185m	>5	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>3	<1	0	
Aluminum	ppm	ASTM D5185m	>7	<u> </u>	0	
Lead	ppm	ASTM D5185m	>12	0	0	
Copper	ppm	ASTM D5185m	>30	3	2	
Tin	ppm	ASTM D5185m	>9	0	0	
Vanadium	ppm	ASTM D5185m	20	0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES	1 1	method	limit/base	current	history1	history2
Boron	nnm	ASTM D5185m	mmubase	0	0	1113t01 yZ
	ppm			0	0	
Barium	ppm	ASTM D5185m		-		
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		3	1	
Calcium	ppm	ASTM D5185m		55	47	
Phosphorus	ppm	ASTM D5185m		276	369	
Zinc	ppm	ASTM D5185m		370	470	
Sulfur	ppm	ASTM D5185m		4206	2635	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	11	3	
Sodium	ppm	ASTM D5185m		2	3	
Potassium	ppm	ASTM D5185m	>20	0	<1	
Water	%	ASTM D6304	>.1	e 2.12	0.005	
ppm Water	ppm	ASTM D6304	>1000	e 21200	50.4	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000		▲ 134681	
Particles >6µm		ASTM D7647	>1300		<u> </u>	
Particles >14µm		ASTM D7647	>160		90	
Particles >21µm		ASTM D7647	>40		22	
Particles >38µm		ASTM D7647	>10		2	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14		▲ 24/22/14	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.35	
AGU NUMBER (AN)	iiiy i∖∪⊓/y			0.37	0.00	


Contact/Location: KURT CONRADT - TYSWAV



60. 50 Abr 40 30 Abnormal 20. Nov2/23

OIL ANALYSIS REPORT





Certificate L2367

Contact/Location: KURT CONRADT - TYSWAV