

# **OIL ANALYSIS REPORT**

## Sample Rating Trend





Turbine

**MOBIL DTE OIL LIGHT (1200 GAL)** 





### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMA	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003727	USP0000863	USP217962
Sample Date		Client Info		18 Nov 2023	31 Jul 2023	14 Feb 2021
	yrs	Client Info		0	0	0
-	yrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	0	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>2	0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m		0	0	<1
Copper	ppm	ASTM D5185m	>5	0	0	<1
Tin	ppm	ASTM D5185m	>5	<1	<1	1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		<1	<1	<1
Calcium	ppm	ASTM D5185m		1	1	1
Phosphorus	ppm	ASTM D5185m		100	100	107
Zinc	ppm	ASTM D5185m		6	18	10
Sulfur	ppm	ASTM D5185m		915	941	950
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	<1
Sodium	ppm	ASTM D5185m		0	0	2
	ppm	ASTM D5185m	>20	0	<1	<1
	%	ASTM D6304	>0.03	0.002	0.001	0.002
ppm Water	ppm	ASTM D6304	>300	22.6	3.4	18.3
FLUID CLEANLINE	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>2500	456	<u>▲</u> 4218	494
Particles >6μm		ASTM D7647	>640	162	<u>▲</u> 862	159
Particles >14μm		ASTM D7647	>80	19	39	23
Particles >21µm		ASTM D7647	>20	6	8	6
Particles >38μm		ASTM D7647	>4	0	1	0
Particles >71μm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	16/15/11	▲ 19/17/12	16/14/12
FLUID DEGRADAT	ΓΙΟΝ	method	limit/base	current	history1	history2



## **OIL ANALYSIS REPORT**







Certificate L2367

Lab Number **Unique Number** 

Test Package : IND 2

: 06010885 : 10750029

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Diagnosed : 20 Nov 2023 Diagnostician : Doug Bogart

MANKATO, MN US 56002

Contact: BRIAN GERMSCHEID brian.germscheid@adm.com

> T: (507)625-5459 F: (507)625-3117

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)