




# PROBLEM SUMMARY

Sample Rating Trend



**WEAR**




Machine Id  
**NORTHWEST 4 (S/N 003-118845)**

Component  
**Compressor**


Fluid  
**{not provided} (--- GAL)**

## COMPONENT CONDITION SUMMARY


### ▲ Ferrous Alloys



### ▲ Viscosity @ 40°C



### ▲ Additives



## RECOMMENDATION

We advise an early resample to confirm this situation.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m >50	▲ <b>75</b>	6	9
Phosphorus	ppm	ASTM D5185m	▲ <b>860</b>	5	4
Zinc	ppm	ASTM D5185m	▲ <b>19</b>	158	298
Visc @ 40°C	cSt	ASTM D445	▲ <b>74.56</b>	40.8	45.8

Customer Id: JBSBEA  
Sample No.: USPM31311  
Lab Number: 06010886  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

**RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Resample	---	---	?	We advise an early resample to confirm this situation.

**HISTORICAL DIAGNOSIS**

**13 Jul 2023 Diag: Doug Bogart**

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



**11 Aug 2021 Diag: Doug Bogart**

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



**05 May 2021 Diag: Doug Bogart**

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Machine Id  
**NORTHWEST 4 (S/N 003-118845)**

Component  
**Compressor**  
Fluid  
**{not provided} (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise an early resample to confirm this situation.

### ▲ Wear

The iron level is abnormal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### ▲ Fluid Condition

The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand or type of oil. Confirmed. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USPM31311</b>	USPM27402	USPM18846
Sample Date	Client Info	<b>18 Nov 2023</b>	13 Jul 2023	11 Aug 2021
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	<b>▲ 75</b>	6	9
Chromium ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel ppm	ASTM D5185m	<b>0</b>	0	<1
Titanium ppm	ASTM D5185m	<b>0</b>	<1	0
Silver ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	<1
Lead ppm	ASTM D5185m >25	<b>0</b>	1	1
Copper ppm	ASTM D5185m >50	<b>&lt;1</b>	<b>▲ 138</b>	<b>▲ 51</b>
Tin ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	0
Antimony ppm	ASTM D5185m	<b>---</b>	---	1
Vanadium ppm	ASTM D5185m	<b>0</b>	<1	0
Cadmium ppm	ASTM D5185m	<b>0</b>	<1	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	<b>0</b>	0	4
Barium ppm	ASTM D5185m	<b>0</b>	547	463
Molybdenum ppm	ASTM D5185m	<b>0</b>	0	0
Manganese ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium ppm	ASTM D5185m	<b>&lt;1</b>	3	<1
Calcium ppm	ASTM D5185m	<b>2</b>	8	8
Phosphorus ppm	ASTM D5185m	<b>▲ 860</b>	5	4
Zinc ppm	ASTM D5185m	<b>▲ 19</b>	158	298
Sulfur ppm	ASTM D5185m	<b>639</b>	583	430

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	<b>3</b>	<1	<1
Sodium ppm	ASTM D5185m	<b>8</b>	19	23
Potassium ppm	ASTM D5185m >20	<b>0</b>	4	0
Water %	ASTM D6304 >0.1	<b>0.025</b>	<b>▲ 0.535</b>	<b>▲ 0.519</b>
ppm Water	ASTM D6304 >1000	<b>254.9</b>	<b>▲ 5353.9</b>	<b>▲ 5191.6</b>

## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>2532</b>	8282	521
Particles >6µm	ASTM D7647 >2500	<b>854</b>	2060	99
Particles >14µm	ASTM D7647 >320	<b>65</b>	99	3
Particles >21µm	ASTM D7647 >80	<b>10</b>	19	0
Particles >38µm	ASTM D7647 >20	<b>0</b>	0	0
Particles >71µm	ASTM D7647 >4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>19/17/13</b>	20/18/14	16/14/9


## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045	<b>0.30</b>	0.48	0.777




# OIL ANALYSIS REPORT


## Additives




## Water (KF)




## Particle Trend



## Particle Count




## Acid Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	▲ 74.56	40.8	45.8

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USPM31311 **Received** : 17 Nov 2023  
**Lab Number** : 06010886 **Diagnosed** : 22 Nov 2023  
**Unique Number** : 10750030 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2

**JBS - BEARDSTOWN**  
 8295 ARENZVILLE RD  
 BEARDSTOWN, IL  
 US 62618  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)