

PROBLEM SUMMARY

Sample Rating Trend

WEAR


SULLAIR 6 (S/N 201402220045)


Component


Compressor


{not provided} (--- GAL)

COMPONENT CONDITION SUMMARY









RECOMMENDATION

We advise an early resample to confirm this situation.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL		
Iron	ppm	ASTM D5185m	>50	△ 39	1	<1		
Phosphorus	ppm	ASTM D5185m		<u> </u>	3	8		
Particles >4µm		ASTM D7647	>10000	14920		408		
Particles >6µm		ASTM D7647	>2500	4 3603		92		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>^</u> 21/19/15		16/14/10		
Visc @ 40°C	cSt	ASTM D445		104.1	41.1	43.3		

Customer Id: JBSBEA Sample No.: USPM31301 Lab Number: 06010888 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample			?	We advise an early resample to confirm this situation.

HISTORICAL DIAGNOSIS

13 Jul 2023 Diag: Doug Bogart

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



11 Aug 2021 Diag: Doug Bogart

WATER



We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Nov 2020 Diag: Doug Bogart

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend


WEAR

SULLAIR 6 (S/N 201402220045)

component

Compressor

{not provided} (--- GAL)



DIAGNOSIS

Recommendation

We advise an early resample to confirm this situation.

Wear

The iron level is abnormal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

▲ Fluid Condition

The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand or type of oil. Confirm oil type. The AN level is acceptable for this fluid.

		Feb2017	Oct2017 Jul2019	Feb2020 Nov2020 J	ulZ023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31301	USPM27404	USPM18838
Sample Date		Client Info		18 Nov 2023	13 Jul 2023	11 Aug 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	△ 39	1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	0	1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>25	0	0	3
Copper	ppm	ASTM D5185m	>50	0	7	3
Tin	ppm	ASTM D5185m	>15	<1	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	5
Barium	ppm	ASTM D5185m		0	671	392
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		<1	3	<1
Calcium	ppm	ASTM D5185m		1	12	12
Phosphorus	ppm	ASTM D5185m		1531	3	8
Zinc	ppm	ASTM D5185m		0	46	107
Sulfur	ppm	ASTM D5185m		5	476	357
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	<1	<1
Sodium	ppm	ASTM D5185m		2	39	46
Potassium	ppm	ASTM D5185m	>20	<1	5	3
Water	%	ASTM D6304	>0.1	0.085	△ 0.434	△ 0.458
ppm Water	ppm	ASTM D6304	>1000	854.7	▲ 4347.3	<u>▲</u> 4585.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	14920		408
Particles >6µm		ASTM D7647	>2500	△ 3603		92
Particles >14µm		ASTM D7647	>320	304		7
Particles >21µm						0
Tartiolog >2 Tarii		ASTM D7647	>80	79		2
Particles >38µm		ASTM D7647 ASTM D7647	>80 >20	79 6		0
Particles >38μm		ASTM D7647	>20	6		0

0.24


mg KOH/g ASTM D8045

0.576

0.463



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: USPM31301 : 06010888

: 10750032 Test Package : IND 2

: 17 Nov 2023 Received Diagnosed Diagnostician

: 22 Nov 2023 : Doug Bogart

JBS - BEARDSTOWN 8295 ARENZVILLE RD BEARDSTOWN, IL US 62618 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: