




PROBLEM SUMMARY

Sample Rating Trend



WATER




Machine Id
VAC 1181700-6 P3 TOP (S/N 5587016)


Component
Pump
Fluid
USPI VAC 100 (--- GAL)

COMPONENT CONDITION SUMMARY


▲ Viscosity @ 40°C




▲ Ferrous Alloys



▲ Additives



▲ Water (KF)



RECOMMENDATION

We advise an early resample to confirm this situation. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>90	▲ 47	9	6
Calcium	ppm	ASTM D5185m	0	▲ 27	0	<1
Phosphorus	ppm	ASTM D5185m	1800	▲ 459	▲ 578	1637
Sulfur	ppm	ASTM D5185m	0	▲ 11129	102	21
Water	%	ASTM D6304	>.1	▲ 0.152	0.055	0.064
ppm Water	ppm	ASTM D6304	>1000	▲ 1529.3	553.0	644.0
Silt	scalar	*Visual	NONE	▲ HEAVY	▲ MODER	NONE
Debris	scalar	*Visual	NONE	▲ MODER	LIGHT	NONE
Visc @ 40°C	cSt	ASTM D445	91	▲ 527.8	▲ 74.71	97.1

Customer Id: JBSBEA
Sample No.: USPM31307
Lab Number: 06010901
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Resample	---	---	?	We advise an early resample to confirm this situation.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

16 Jul 2023 Diag: Doug Bogart

SEDIMENT



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. The oil viscosity is lower than normal. This plus the additive levels indicates the addition of a different brand or type of oil. Confirmed. The AN level is acceptable for this fluid.

[view report](#)



17 Nov 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



27 Feb 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
VAC 1181700-6 P3 TOP (S/N 5587016)

Component
Pump
Fluid
USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

We advise an early resample to confirm this situation. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

An increase in the iron level is noted.

Contamination

There is a high amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand or type of oil. Confirmed. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM31307	USPM27398	USPM23663
Sample Date	Client Info	18 Nov 2023	16 Jul 2023	17 Nov 2022
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >90	▲ 47	9	6
Chromium	ppm	ASTM D5185m >5	<1	0	0
Nickel	ppm	ASTM D5185m >5	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	<1	0
Silver	ppm	ASTM D5185m >3	<1	0	0
Aluminum	ppm	ASTM D5185m >7	2	1	0
Lead	ppm	ASTM D5185m >12	0	0	0
Copper	ppm	ASTM D5185m >30	5	<1	<1
Tin	ppm	ASTM D5185m >9	0	0	<1
Antimony	ppm	ASTM D5185m	---	---	---
Vanadium	ppm	ASTM D5185m	0	<1	0
Cadmium	ppm	ASTM D5185m	1	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	7	0	<1
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	<1	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 0	5	2	0
Calcium	ppm	ASTM D5185m 0	▲ 27	0	<1
Phosphorus	ppm	ASTM D5185m 1800	▲ 459	▲ 578	1637
Zinc	ppm	ASTM D5185m 0	<1	0	0
Sulfur	ppm	ASTM D5185m 0	▲ 11129	102	21

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >60	2	15	8
Sodium	ppm	ASTM D5185m	8	6	0
Potassium	ppm	ASTM D5185m >20	7	1	0
Water	%	ASTM D6304 >.1	▲ 0.152	0.055	0.064
ppm Water	ppm	ASTM D6304 >1000	▲ 1529.3	553.0	644.0






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	---	---	▲ 33250
Particles >6µm	ASTM D7647 >1300	---	---	▲ 1486
Particles >14µm	ASTM D7647 >160	---	---	41
Particles >21µm	ASTM D7647 >40	---	---	11
Particles >38µm	ASTM D7647 >10	---	---	1
Particles >71µm	ASTM D7647 >3	---	---	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	---	---	▲ 22/18/13

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	0.77	0.19	0.15


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ HEAVY	▲ MODER	NONE
Debris	scalar	*Visual	▲ MODER	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 91	▲ 527.8	▲ 74.71	97.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM31307 **Received** : 17 Nov 2023
Lab Number : 06010901 **Diagnosed** : 22 Nov 2023
Unique Number : 10750045 **Diagnostician** : Doug Bogart
Test Package : IND 2

JBS - BEARDSTOWN
 8295 ARENZVILLE RD
 BEARDSTOWN, IL
 US 62618
 Contact:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: