



# PROBLEM SUMMARY


Sample Rating Trend

VISUAL METAL




Machine Id  
**TENDER MV PUMP (S/N 5590472)**

Component  
**Vacuum Pump**  
Fluid  
**USPI VAC 100 (--- GAL)**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you inspect for the source(s) of wear. We advise an early resample to confirm this situation. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Iron	ppm	ASTM D5185m	>20	271	2	6
Calcium	ppm	ASTM D5185m	0	109	<1	0
Phosphorus	ppm	ASTM D5185m	1800	548	1179	1139
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	11180	4	0
Water	%	ASTM D6304	>.1	0.850	0.084	0.018
ppm Water	ppm	ASTM D6304	>1000	8500	848.2	182.1
White Metal	scalar	*Visual	NONE	HEAVY	NONE	NONE
Silt	scalar	*Visual	NONE	HEAVY	NONE	NONE
Debris	scalar	*Visual	NONE	HEAVY	LIGHT	NONE
Emulsified Water	scalar	*Visual	>.1	0.2%	NEG	NEG
Visc @ 40°C	cSt	ASTM D445	91	565.6	113	94.1

Customer Id: JBSBEA  
Sample No.: USPM31300  
Lab Number: 06010906  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Resample	---	---	?	We advise an early resample to confirm this situation.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

## HISTORICAL DIAGNOSIS

### 13 Jul 2023 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 27 Feb 2022 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



VISUAL METAL



Machine Id  
**TENDER MV PUMP (S/N 5590472)**

Component  
**Vacuum Pump**  
Fluid  
**USPI VAC 100 (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you inspect for the source(s) of wear. We advise an early resample to confirm this situation. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

The iron level is severe. High concentration of visible metal present.

### Contamination

High concentration of visible dirt/debris present in the oil. There is a high amount of visible silt present in the sample. There is a moderate concentration of water present in the oil.

### Fluid Condition

The oil viscosity is higher than normal. This plus the additive levels indicates the addition of a different brand, or type of oil. Confirmed. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USPM31300</b>	USPM27399	USPM21032
Sample Date	Client Info		<b>18 Nov 2023</b>	13 Jul 2023	27 Feb 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>271</b>	2	6
Chromium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >20	<b>1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>2</b>	1	<1
Lead	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m >20	<b>17</b>	0	0
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>2</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>3</b>	0	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>2</b>	<1	0
Magnesium	ppm	ASTM D5185m 0	<b>8</b>	3	0
Calcium	ppm	ASTM D5185m 0	<b>109</b>	<1	0
Phosphorus	ppm	ASTM D5185m 1800	<b>548</b>	1179	1139
Zinc	ppm	ASTM D5185m 0	<b>0</b>	0	0
Sulfur	ppm	ASTM D5185m 0	<b>11180</b>	4	0

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>5</b>	2	14
Sodium	ppm	ASTM D5185m	<b>12</b>	<1	0
Potassium	ppm	ASTM D5185m >20	<b>20</b>	2	<1
Water	%	ASTM D6304 >.1	<b>0.850</b>	0.084	0.018
ppm Water	ppm	ASTM D6304 >1000	<b>8500</b>	848.2	182.1






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>---</b>	<b>65462</b>	<b>114278</b>
Particles >6µm	ASTM D7647	>1300	<b>---</b>	<b>12134</b>	<b>15760</b>
Particles >14µm	ASTM D7647	>160	<b>---</b>	149	142
Particles >21µm	ASTM D7647	>40	<b>---</b>	20	30
Particles >38µm	ASTM D7647	>10	<b>---</b>	0	7
Particles >71µm	ASTM D7647	>3	<b>---</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>---</b>	<b>23/21/14</b>	<b>24/21/14</b>

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	<b>1.04</b>	0.049	0.063


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	HEAVY	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	HEAVY	NONE
Debris	scalar	*Visual	NONE	HEAVY	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 91	565.6	113	94.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USPM31300 **Received** : 17 Nov 2023  
**Lab Number** : 06010906 **Diagnosed** : 22 Nov 2023  
**Unique Number** : 10750050 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2

**JBS - BEARDSTOWN**  
 8295 ARENZVILLE RD  
 BEARDSTOWN, IL  
 US 62618  
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: