

PROBLEM SUMMARY

Sample Rating Trend




B-7 FES (S/N CL1580)

Component

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL	
Particles >4µm	ASTM D7647 >	>10000	<u> </u>	<u>115080</u>	<u>48587</u>	
Particles >6µm	ASTM D7647	>2500	30394	▲ 32225	<u></u> 5111	
Particles >14μm	ASTM D7647 >	>320	<u>^</u> 710	<u>▲</u> 535	135	
Particles >21μm	ASTM D7647	>80	<u> </u>	45	30	
Oil Cleanliness	ISO 4406 (c) >	>20/18/15	<u>4</u> 24/22/17	<u>4</u> 24/22/16	<u>\$\Delta\$ 23/20/14</u>	

Customer Id: CARBEAIL Sample No.: USP0003647 Lab Number: 06010917 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

16 Jul 2023 Diag: Doug Bogart

WATER



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



22 Mar 2023 Diag: Doug Bogart

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



17 Nov 2022 Diag: Doug Bogart

WATER




We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. There is a trace of moisture present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service





OIL ANALYSIS REPORT

Sample Rating Trend



ISO

B-7 FES (S/N CL1580)

Component

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

D	IΑ	GI	NC	2	IS.
-	ᇄ	u	V	\mathbf{c}	U

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a trace of moisture present in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr2015	Jan 2022 Nov2022	Mar2023 Jul2023	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0003647	USP255371	USP249480
Sample Date		Client Info		18 Nov 2023	16 Jul 2023	22 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	<1	2
Chromium	ppm	ASTM D5185m	>2	0	<1	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		1	0	0
Phosphorus	ppm	ASTM D5185m		1	0	<1
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	33	2	28
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m		0	0	<1
Water	%	ASTM D6304	>0.01	0.018	▲ 0.021	0.008
ppm Water	ppm	ASTM D6304	>100	180.1	<u>^</u> 218.2	85.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u> </u>	<u> </u>	▲ 48587
Particles >6µm		ASTM D7647	>2500	<u>^</u> 30394	▲ 32225	<u></u> ▲ 5111
Particles >14μm		ASTM D7647	>320	<u>^</u> 710	<u>▲</u> 535	135
Particles >21µm		ASTM D7647	>80	<u>^</u> 90	45	30
Particles >38µm		ASTM D7647	>20	1	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>4</u> 24/22/17	<u>4</u> 24/22/16	<u>\$\text{\Delta}\$ 23/20/14</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.012	0.014	0.014



OIL ANALYSIS REPORT





Certificate L2367

Unique Number

Sample No. Lab Number

Test Package : IND 2

: USP0003647 : 06010917 : 10750061

Received Diagnosed

: 20 Nov 2023 Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) BEARDSTOWN, IL US 62618 Contact:

T: (217)323-3774 F: