


OIL ANALYSIS REPORT

Machine Id | WC-9220-0103-5 Chiller #3

Component Chiller

YORK TYPE K (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Insufficient sample was received to confirm all the routine laboratory tests.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2023	Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0836497	WC0784801	
Sample Date		Client Info		13 Nov 2023	19 Jun 2023	
Machine Age	hrs	Client Info		18710	17407	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	
Chromium	ppm	ASTM D5185m	>2	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	0	
Lead	ppm	ASTM D5185m	>2	0	0	
Copper	ppm	ASTM D5185m	>8	0	<1	
Tin	ppm	ASTM D5185m	>4	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	0	0	<1	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	0	0	0	
Magnesium	ppm	ASTM D5185m	0	0	0	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	5	1	0	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	10	14	0	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	7	8	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.01	0.049	0.074	
ppm Water	ppm	ASTM D6304	>100	499.9	744.7	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1039	2470	
Particles >6µm		ASTM D7647	>2500	195	1091	
Particles >14µm		ASTM D7647	>320	10	68	
Particles >21µm		ASTM D7647	>80	3	12	
Particles >38µm		ASTM D7647	>20	1	0	
Particles >71µm		ASTM D7647	>4	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/15/10	18/17/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Asid Number (AN)	I/OII/-	ACTM DODAE	0.00	0.010	0.00	

Acid Number (AN)


mg KOH/g ASTM D8045 0.03

0.03

0.012



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: WC0836497 : 06010957 : 10750101 Test Package : PLANT

Received : 17 Nov 2023

Diagnosed : 04 Dec 2023 Diagnostician

: Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

10840 Guilford Road, Suites 406-407

Annapolis Junction, MD

US 20701 Contact: Susan Nord

susan.nord@chugachgov.com T: (301)688-6363

F: (443)479-5666 Contact/Location: Susan Nord - CHUANN