


Area  
**PO-6030 [B12000031]**  
 Machine Id  
**INGERSOLL RAND CBV304834 - MARATHON EQUIPMENT**  
 Component  
**Compressor**



**DIAGNOSIS**

**Recommendation**

Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

**Contamination**

There is no indication of any contamination in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION**    method    limit/base    current    history1    history2

Sample Number	Client Info		<b>UCP06010988</b>	UCP05551491	UCP05485218
Sample Date	Client Info		<b>20 Jul 2023</b>	06 May 2022	19 Feb 2022
Machine Age	hrs	Client Info	<b>17031</b>	10207	9081
Oil Age	hrs	Client Info	<b>2203</b>	7000	6000
Oil Changed		Client Info	<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

**CONTAMINATION**    method    limit/base    current    history1    history2

Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG
-------	-----------	------	------------	-----	-----

**WEAR METALS**    method    limit/base    current    history1    history2

Iron	ppm	ASTM D5185m	>50	<b>0</b>	<1	<1
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m	>15	<b>2</b>	<1	0
Antimony	ppm	ASTM D5185m		<b>---</b>	---	<1
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	0

**ADDITIVES**    method    limit/base    current    history1    history2

Boron	ppm	ASTM D5185m	0	<b>0</b>	2	0
Barium	ppm	ASTM D5185m	700	<b>135</b>	225	201
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	0	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	0	<b>2</b>	<1	0
Calcium	ppm	ASTM D5185m	0	<b>6</b>	4	4
Phosphorus	ppm	ASTM D5185m	0	<b>4</b>	10	12
Zinc	ppm	ASTM D5185m	0	<b>&lt;1</b>	7	3
Sulfur	ppm	ASTM D5185m	630	<b>473</b>	390	338



**CONTAMINANTS**    method    limit/base    current    history1    history2

Silicon	ppm	ASTM D5185m	>25	<b>&lt;1</b>	1	<1
Sodium	ppm	ASTM D5185m		<b>43</b>	45	46
Potassium	ppm	ASTM D5185m	>20	<b>3</b>	3	3

**FLUID DEGRADATION**    method    limit/base    current    history1    history2

Acid Number (AN)	mg KOH/g	ASTM D8045	0.200	<b>0.25</b>	0.22	0.13
------------------	----------	------------	-------	-------------	------	------


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	47.6	<b>52.1</b>	50.6	50.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : UCP06010988 **Received** : 17 Nov 2023  
**Lab Number** : **06010988** **Diagnosed** : 21 Nov 2023  
**Unique Number** : 10750132 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2

**PATTONS INC - BIRMINGHAM**  
 20 MONROE DR  
 PELHAM, AL  
 US 35124  
 Contact: MARK FLOYD  
 mark.floyd@pattonsinco.com  
 T:  
 F: (205)780-4508

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)