


# PROBLEM SUMMARY

Sample Rating Trend




**WEAR**




Area  
**FORMALDEHYDE PLANT**  
Machine Id  
**B1 Blower West End**  
Component  
**Inboard Blower**  
Fluid  
**ROYAL PURPLE SYNFILM 46 (2 GAL)**

## COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



▲ Particle Trend



## RECOMMENDATION

Viscosity has lowered to an ISO 32 weight oil. Lead and Copper wear are present in the sample at a low but substantial change from previous samples. Investigate possible changes in machine using vibration and load trending to verify if wear is causing damage. No other action required at this time. Resample at next normal interval.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	ABNORMAL
Lead	ppm	ASTM D5185m	>20	▲ 14	▲ 13	0
Copper	ppm	ASTM D5185m	>20	▲ 14	▲ 11	0
Particles >4µm		ASTM D7647	>2500	▲ 13667	1405	---
Particles >6µm		ASTM D7647	>640	▲ 3014	382	---
Particles >14µm		ASTM D7647	>80	▲ 186	67	---
Particles >21µm		ASTM D7647	>20	▲ 45	33	---
Oil Cleanliness		ISO 4406 (c)	>18/16/13	▲ 21/19/15	18/16/13	---

Customer Id: HEXHOPAR  
Sample No.: PLS0000743  
Lab Number: 06011433  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Mike Johnson +1 (615)771-6030  
[mike.johnson@amrri.com](mailto:mike.johnson@amrri.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 12 Sep 2023 Diag: Mike Johnson

#### WEAR



Filter quality indicates an oil change has been conducted. Viscosity has lowered to an ISO 32 weight oil. Lead and Copper wear are present in the sample at a low but substantial change from previous samples. Investigate possible changes in machine using vibration and load trending to verify if wear is causing damage. No other action required at this time. Resample at next normal interval. Lead and Copper particle wear is elevated. Particle contamination is on par with new unfiltered oil. Filtration can help extend machine life. Fluid health indicators are acceptable for continued use and indicate an oil change has taken place since the last sample.

view report



### 10 Jun 2023 Diag: Mike Johnson

#### VISUAL METAL



No particle count was conducted due to visible particulate in the sample. Filter oil if possible using B6=75 filter media or better and then resample with good sampling procedures. Wear particles are low and acceptable. Particle counting was not conducted due to visible particulate in the oil. Filtration and proper sampling techniques can improve precision of information. Fluid Viscosity is higher than the specification provided, but consistent with previous samples. If the specification is in error, contact mike.johnson@amrri.com with details.

view report



### 27 Apr 2023 Diag: Mike Johnson

#### VISCOSITY




Filter oil if possible using B6=75 filter media or better. No other action required at this time. Resample at next normal interval. Wear particles are low and acceptable. Particle contamination is elevated. Filtration can help to extend machine life. Fluid viscosity is indicating an 46 oil in use. If oil in use is an ISO 46 weight oil and you would like to change the reference on file, contact Mike.Johnson@amrri.com.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



**WEAR**



Area  
**FORMALDEHYDE PLANT**  
Machine Id  
**B1 Blower West End**  
Component  
**Inboard Blower**  
Fluid  
**ROYAL PURPLE SYNFILM 46 (2 GAL)**

## DIAGNOSIS

### Recommendation

Viscosity has lowered to an ISO 32 weight oil. Lead and Copper wear are present in the sample at a low but substantial change from previous samples. Investigate possible changes in machine using vibration and load trending to verify if wear is causing damage. No other action required at this time. Resample at next normal interval.

### Wear

Lead and Copper particle wear is elevated.

### Contamination

Particle contamination is on par with new unfiltered oil. Filtration can help extend machine life.

### Fluid Condition

Fluid health indicators are acceptable for continued use.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PLS0000743</b>	PLS0000748	PLS0000609
Sample Date	Client Info	<b>14 Nov 2023</b>	12 Sep 2023	10 Jun 2023
Machine Age	mths	Client Info	2	18
Oil Age	mths	Client Info	2	18
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	<b>14</b>	14	25
Iron	ppm	ASTM D5185m >20	<b>0</b>	0
Chromium	ppm	ASTM D5185m >20	<b>0</b>	0
Nickel	ppm	ASTM D5185m >20	<b>0</b>	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1
Silver	ppm	ASTM D5185m	<b>&lt;1</b>	0
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	0
Lead	ppm	ASTM D5185m >20	<b>▲ 14</b>	▲ 13
Copper	ppm	ASTM D5185m >20	<b>▲ 14</b>	▲ 11
Tin	ppm	ASTM D5185m >20	<b>&lt;1</b>	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0
Barium	ppm	ASTM D5185m	<b>0</b>	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1
Magnesium	ppm	ASTM D5185m	<b>28</b>	37
Calcium	ppm	ASTM D5185m	<b>0</b>	<1
Phosphorus	ppm	ASTM D5185m	<b>28</b>	50
Zinc	ppm	ASTM D5185m	<b>41</b>	39
Sulfur	ppm	ASTM D5185m	<b>16284</b>	16205


## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>2</b>	2
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	2
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0


## INFRA-RED

method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0
Nitration	Abs/cm	*ASTM D7624	<b>2.5</b>	2.3
Sulfation	Abs/.1mm	*ASTM D7415	<b>20.2</b>	19.3


# OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ <b>13667</b>	1405	---
Particles >6µm	ASTM D7647	>640	▲ <b>3014</b>	382	---
Particles >14µm	ASTM D7647	>80	▲ <b>186</b>	67	---
Particles >21µm	ASTM D7647	>20	▲ <b>45</b>	33	---
Particles >38µm	ASTM D7647	>4	<b>1</b>	2	---
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ <b>21/19/15</b>	18/16/13	---




FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm *ASTM D7414		<b>13.7</b>	13.0	24.8
Acid Number (AN)	mg KOH/g ASTM D8045	0.25	<b>0.32</b>	0.34	0.37




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	<b>NONE</b>	NONE	▲ LIGHT
Yellow Metal	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar *Visual	NONE	<b>NONE</b>	NONE	▲ MODER
Sand/Dirt	scalar *Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar *Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar *Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar *Visual		<b>NEG</b>	NEG	NEG
Free Water	scalar *Visual		<b>NEG</b>	NEG	NEG



FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	46	<b>32.5</b>	31.8	▲ 45.3



SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000743 **Received** : 17 Nov 2023  
**Lab Number** : **06011433** **Diagnosed** : 06 Dec 2023  
**Unique Number** : 10750577 **Diagnostician** : Mike Johnson  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ, PrtCount )

**HEXION - HOPE PLANT**  
 185 N INDUSTRIAL DR  
 HOPE, AR  
 US 71801  
 Contact: JOSEPH MURPHY  
 joseph.murphy@hexion.com;mike.johnson@amrri.com  
 T: (870)722-7305  
 F: (870)722-5678

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)