


KAESER COMPRESSORS Built for a lifetime:

KAESER SM 11 1128895 (S/N 1011)


Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY



Sample Rating Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

THOBEENINTIO	201112	-00210				
Sample Status				ABNORMAL	NORMAL	ABNORMAL
Water	%	ASTM D6304	>0.05	A 0.279	0.032	0.031
ppm Water	ppm	ASTM D6304	>500	🔺 2793.3	320.9	313.6
Particles >14µm		ASTM D7647	>80	🔺 164		
Particles >21µm		ASTM D7647	>20	6		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		

Customer Id: WOBWOB Sample No.: KCPA000856 Lab Number: 06011524 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net


To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

18 Jun 2021 Diag: Angela Borella



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view repor

25 Oct 2019 Diag: Don Baldridge

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

SAMPLE INCODMATION



Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.



SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA000856	KCP42187	KCP31543
Sample Date		Client Info		30 Oct 2023	18 Jun 2021	20 Oct 2020
Machine Age	hrs	Client Info		44890	40174	39199
Oil Age	hrs	Client Info		0	975	1673
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	
						history2
Iron	ppm	ASTM D5185m		2	<1	1
Chromium	ppm	ASTM D5185m		<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		0	0	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m		11	1	2
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	2
Barium	ppm	ASTM D5185m	90	0	58	28
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	0	87	69
Calcium	ppm	ASTM D5185m	0	0	2	2
Phosphorus	ppm	ASTM D5185m	0	0	3	3
Zinc	ppm	ASTM D5185m	0	0	0	4
Sulfur	ppm	ASTM D5185m	23500	18957	18597	19016
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	1
Sodium	ppm	ASTM D5185m	220	2	19	13
Potassium	ppm	ASTM D5185m	>20	<1	3	3
Water	%	ASTM D510301		0.279	0.032	0.031
ppm Water	ppm	ASTM D0304 ASTM D6304	>500	2793.3	320.9	313.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6927		
Particles >6µm		ASTM D7647		1264		
Particles >14µm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 20/17/15		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A 1151 1 (ASS			1.0			

Acid Number (AN) mg KOH/g A

mg KOH/g ASTM D8045 1.0

0.36 0.336 0.375

Report Id: WOBWOB [WUSCAR] 06011524 (Generated: 11/21/2023 14:19:14) Rev: 1

Contact/Location: J COOPER - WOBWOB



Water (ppm)

600

50

Ê 40

KOH/g)

Pio O.2

60

55

<u>်</u> 50

-73 45 Bas

40

ă

Abnorma

Se 35


OIL ANALYSIS REPORT

method

*Visual

limit/base


NONE





current

NONE




history1

MODER

history2

NONE



Contact/Location: J COOPER - WOBWOB