

PROBLEM SUMMARY

Sample Rating Trend ISO


KAESER 8103036

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >6µm	ASTM D7647	>1300	<u> </u>	▲ 5014					
Particles >14μm	ASTM D7647	>80	570	<u></u> 174					
Particles >21µm	ASTM D7647	>20	128	20					
Particles >38μm	ASTM D7647	>4	<u> </u>	0					
Oil Cleanliness	ISO 4406 (c)	>/17/13	23/21/16	<u>22/20/15</u>					

Customer Id: TWRFLI Sample No.: KCPA009051 Lab Number: 06011526 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 Jan 2023 Diag: Angela Borella

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT



KAESER 8103036

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan 2023	Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA009051	KCP47495D	
Sample Date		Client Info		07 Nov 2023	23 Jan 2023	
Machine Age	hrs	Client Info		15892	9310	
Oil Age	hrs	Client Info		0	9310	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	9	12	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	0	<1	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	0	3	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	12672	13593	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		1	0	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
Water	%	ASTM D6304	>0.05	0.007	0.003	
ppm Water	ppm	ASTM D6304	>500	72.8	28.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		65630	28039	
Particles >6µm		ASTM D7647	>1300	<u> </u>	△ 5014	
Particles >14µm		ASTM D7647	>80	<u></u> 570	<u> </u>	
Particles >21µm		ASTM D7647	>20	<u> </u>	20	
Particles >38μm		ASTM D7647	>4	<u> </u>	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	23/21/16	<u>22/20/15</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A si al Niversala au (ANI)	I/OII/-	ACTM DODAE	1.0	0.07	0.00	

Acid Number (AN)


mg KOH/g ASTM D8045 1.0

0.23

0.27



OIL ANALYSIS REPORT







Sample No. Lab Number **Unique Number**

: 06011526

: KCPA009051 : 10750670

Received Diagnosed

: 17 Nov 2023 : 21 Nov 2023

Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

49 FISH HATCHERY RD FLINTVILLE, TN US 37355

Contact: Service Manager

T: F: