




PROBLEM SUMMARY

Sample Rating Trend




Machine Id
6825515 (S/N 2076)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	ASTM D7647	>1300	▲ 5478	▲ 16294	▲ 7482
Particles >14µm	ASTM D7647	>80	▲ 1037	▲ 6539	▲ 2908
Particles >21µm	ASTM D7647	>20	▲ 209	▲ 1457	▲ 1124
Particles >38µm	ASTM D7647	>4	▲ 8	▲ 109	▲ 101
Particles >71µm	ASTM D7647	>3	▲ 4	▲ 4	▲ 5
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 21/20/17	▲ 21/20	▲ 20/19

Customer Id: PILWIN
Sample No.: KCPA006442
Lab Number: 06011532
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

01 Mar 2022 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



14 Apr 2021 Diag: Don Baldrige

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
6825515 (S/N 2076)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation
 No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a high amount of particulates present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA006442	KCP38285	KCP11027
Sample Date	Client Info		07 Nov 2023	01 Mar 2022	14 Apr 2021
Machine Age	hrs	Client Info	25376	14608	7056
Oil Age	hrs	Client Info	0	3000	3000
Oil Changed	Client Info		N/A	Changed	Not Chngd
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	0	0
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	<1	0	1
Lead	ppm	ASTM D5185m >10	0	0	<1
Copper	ppm	ASTM D5185m >50	8	10	3
Tin	ppm	ASTM D5185m >10	<1	0	<1
Antimony	ppm	ASTM D5185m	---	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	10
Barium	ppm	ASTM D5185m 90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 90	0	0	41
Calcium	ppm	ASTM D5185m 2	0	0	0
Phosphorus	ppm	ASTM D5185m	0	4	7
Zinc	ppm	ASTM D5185m	0	0	23
Sulfur	ppm	ASTM D5185m	15944	15126	18650

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	<1	0
Sodium	ppm	ASTM D5185m	1	0	11
Potassium	ppm	ASTM D5185m >20	0	0	5
Water	%	ASTM D6304 >0.05	0.008	0.004	0.029
ppm Water	ppm	ASTM D6304 >500	81.9	44.5	294.2






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		12500	21680	17000
Particles >6µm	ASTM D7647 >1300		▲ 5478	▲ 16294	▲ 7482
Particles >14µm	ASTM D7647 >80		▲ 1037	▲ 6539	▲ 2908
Particles >21µm	ASTM D7647 >20		▲ 209	▲ 1457	▲ 1124
Particles >38µm	ASTM D7647 >4		▲ 8	▲ 109	▲ 101
Particles >71µm	ASTM D7647 >3		▲ 4	▲ 4	▲ 5
Oil Cleanliness	ISO 4406 (c) >--/17/13		▲ 21/20/17	▲ 21/20	▲ 20/19

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	0.25	0.41	0.382

OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual NONE	NONE	NONE	NONE
Silt	scalar	*Visual NONE	NONE	NONE	NONE
Debris	scalar	*Visual NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual NONE	NONE	NONE	NONE
Appearance	scalar	*Visual NORML	NORML	NORML	NORML
Odor	scalar	*Visual NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual >0.05	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

PARAMETER	method	limit/base	current	history1	history2
FLUID PROPERTIES					
Visc @ 40°C	cSt	ASTM D445 46	44.7	50.2	43.8

PARAMETER	method	limit/base	current	history1	history2
SAMPLE IMAGES					
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006442 **Received** : 17 Nov 2023
Lab Number : 06011532 **Diagnosed** : 21 Nov 2023
Unique Number : 10750676 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

PILGRIMS PRIDE FEED MILL
 205 EDGEWOOD DR
 WINGATE, NC
 US 28174
 Contact: THOMAS STONER JR
 THOMAS.STONEJR2@JBSSA.COM
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)