


# **PROBLEM SUMMARY**

### Area **E610 LYOS [3001976]** Machine Id **14AR06 (S/N 06FR850)** Component

Refrigeration Compressor Fluid SOLEST LT-32 (4 GAL)

# COMPONENT CONDITION SUMMARY



## RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status				MARGINAL	NORMAL	NORMAL
Water	%	ASTM D6304	>0.01	<b>0.026</b>	0.018	0.015
ppm Water	ppm	ASTM D6304	>100	<b>A</b> 265.1	188.3	151.6

Customer Id: TALCLA Sample No.: WC0871221 Lab Number: 06011535 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### **HISTORICAL DIAGNOSIS**

### 15 Aug 2023 Diag: Doug Bogart






No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

# 05 May 2023 Diag: Doug Bogart



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 10 Feb 2023 Diag: Angela Borella



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

### Area **E610 LYOS [3001976]** Machine Id **14AR06 (S/N 06FR850)** Component

Refrigeration Compressor Fluid SOLEST LT-32 (4 GAL)

## DIAGNOSIS

### A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

## Wear


All component wear rates are normal.

# Contamination

There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





	<b>JATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0871221	WC0806761	WC0792604
Sample Date		Client Info		10 Nov 2023	15 Aug 2023	05 May 2023
Machine Age	mths	Client Info		0	0	0
Oil Age	mths	Client Info		0	0	0
Oil Changed		Client Info		N/A	Not Changd	N/A
Sample Status				MARGINAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>8	<1	0	0
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	0	<1
Lead	ppm	ASTM D5185m	>2	<1	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	<1	0	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	<1	2
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		0	0	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	5	1	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm					
Folassium		ASTM D5185m	>20	<1	0	0
	%	ASTM D5185m		<1 <b>0.026</b>	0 0.018	0 0.015
Water			>0.01			
Water	% ppm	ASTM D6304	>0.01	<b>A</b> 0.026	0.018	0.015
Water ppm Water FLUID CLEANLIN	% ppm	ASTM D6304 ASTM D6304	>0.01 >100	▲ 0.026 ▲ 265.1	0.018 188.3	0.015 151.6
Water ppm Water FLUID CLEANLIN Particles >4μm	% ppm	ASTM D6304 ASTM D6304 method	>0.01 >100 limit/base	<ul> <li>0.026</li> <li>265.1</li> <li>current</li> </ul>	0.018 188.3 history1	0.015 151.6 history2
Water ppm Water FLUID CLEANLIN Particles >4μm Particles >6μm	% ppm	ASTM D6304 ASTM D6304 method ASTM D7647	>0.01 >100 limit/base >10000	<ul> <li>0.026</li> <li>265.1</li> <li>current</li> <li>348</li> </ul>	0.018 188.3 history1 1490	0.015 151.6 history2 1436
Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm	% ppm	ASTM D6304 ASTM D6304 method ASTM D7647 ASTM D7647	>0.01 >100 limit/base >10000 >2500	<ul> <li>0.026</li> <li>265.1</li> <li>current</li> <li>348</li> <li>64</li> </ul>	0.018 188.3 history1 1490 348	0.015 151.6 history2 1436 307
Water ppm Water FLUID CLEANLIN Particles >4μm Particles >6μm Particles >14μm Particles >21μm	% ppm	ASTM D6304 ASTM D6304 method ASTM D7647 ASTM D7647 ASTM D7647	>0.01 >100 limit/base >10000 >2500 >320	<ul> <li>0.026</li> <li>265.1</li> <li>current</li> <li>348</li> <li>64</li> <li>12</li> </ul>	0.018 188.3 history1 1490 348 23	0.015 151.6 history2 1436 307 15
Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm	% ppm	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647	>0.01 >100 limit/base >10000 >2500 >320 >80 >20	<ul> <li>0.026</li> <li>265.1</li> <li>current</li> <li>348</li> <li>64</li> <li>12</li> <li>4</li> </ul>	0.018 188.3 history1 1490 348 23 4	0.015 151.6 history2 1436 307 15 4
Water ppm Water	% ppm	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>0.01 >100 limit/base >10000 >2500 >320 >80 >20	<ul> <li>0.026</li> <li>265.1</li> <li>current</li> <li>348</li> <li>64</li> <li>12</li> <li>4</li> <li>0</li> </ul>	0.018 188.3 history1 1490 348 23 4 0	0.015 151.6 history2 1436 307 15 4 1
Water ppm Water FLUID CLEANLIN Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm	% ppm JESS	ASTM D6304 ASTM D6304 Method ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>0.01 >100 limit/base >10000 >2500 >320 >320 >80 >20 >4	<ul> <li>▲ 0.026</li> <li>▲ 265.1</li> <li>Current</li> <li>348</li> <li>64</li> <li>12</li> <li>4</li> <li>0</li> <li>0</li> </ul>	0.018 188.3 history1 1490 348 23 4 0 0 0	0.015 151.6 history2 1436 307 15 4 1 0




# **OIL ANALYSIS REPORT**











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPER	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		33.5	34.0	33.4
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color				- Sector		



Bottom



: 17 Nov 2023

: 29 Nov 2023

: Jonathan Hester

12 Code Aug31/20. Vov21/22 May29/19 0ct26/21 **GRIFOLS TALECRIS PHARMACEUTICAL** : WearCheck USA - 501 Madison Ave., Cary, NC 27513 8368 US 70 WEST

CLAYTON, NC US 27520 Contact: KEN TERRY kenneth.terry@grifols.com T: (919)359-4362 F: (919)359-4767

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: PrtCount)

: WC0871221

:06011535

: 10750679

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received

Diagnosed

Diagnostician

Certificate L2367

Contact/Location: KEN TERRY - TALCLA

20 8

4406

1999 Clea

6

14