


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
6371495 (S/N 1882)

Component
Compressor

Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count on this sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | | KCPA006453 | KCP38279 | KCP11029 |
| Sample Date | Client Info | | | 06 Nov 2023 | 01 Mar 2022 | 14 Apr 2021 |
| Machine Age | hrs | Client Info | | 13940 | 9551 | 5239 |
| Oil Age | hrs | Client Info | | 0 | 3000 | 3000 |
| Oil Changed | Client Info | | | N/A | Changed | Not Chngd |
| Sample Status | | | | NORMAL | ABNORMAL | ABNORMAL |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | >50 | 0 | <1 | <1 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | 0 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | 3 | <1 | <1 |
| Lead | ppm | ASTM D5185m | >10 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m | >50 | 9 | 11 | 3 |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | <1 |
| Antimony | ppm | ASTM D5185m | | --- | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |




| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | 10 |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | 90 | 0 | 12 | 53 |
| Calcium | ppm | ASTM D5185m | 2 | 0 | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | 0 | 5 | 21 |
| Zinc | ppm | ASTM D5185m | | 17 | 57 | 37 |
| Sulfur | ppm | ASTM D5185m | | 16572 | 15952 | 18282 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m | >25 | <1 | 1 | 0 |
| Sodium | ppm | ASTM D5185m | | 1 | 10 | 17 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 5 | 6 |
| Water | % | ASTM D6304 | >0.05 | 0.021 | 0.013 | 0.038 |
| ppm Water | ppm | ASTM D6304 | >500 | 211.7 | 134.1 | 381.1 |

| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--|--------------|------------|------------|----------|----------|
| Particles >4µm | | ASTM D7647 | | --- | 10639 | 16925 |
| Particles >6µm | | ASTM D7647 | >1300 | --- | ▲ 6701 | ▲ 5381 |
| Particles >14µm | | ASTM D7647 | >80 | --- | ▲ 2450 | ▲ 807 |
| Particles >21µm | | ASTM D7647 | >20 | --- | ▲ 627 | ▲ 263 |
| Particles >38µm | | ASTM D7647 | >4 | --- | ▲ 56 | ▲ 17 |
| Particles >71µm | | ASTM D7647 | >3 | --- | 3 | 1 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | --- | ▲ 20/18 | ▲ 20/17 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.34 | 0.37 | 0.362 |


OIL ANALYSIS REPORT







| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|--------------|----------|
| White Metal | scalar | *Visual | NONE | MODER | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|-------------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46 | 44.4 | 44.1 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA006453 **Received** : 20 Nov 2023
Lab Number : 06012403 **Diagnosed** : 21 Nov 2023
Unique Number : 10751547 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

PILGRIMS PRIDE FEED MILL
 205 EDGEWOOD DR
 WINGATE, NC
 US 28174
 Contact: THOMAS STONER JR
 THOMAS.STONEJR2@JBSSA.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: