


OIL ANALYSIS REPORT



NORMAL



7059482 (S/N 1119)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2022	Oct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006908	KCP51896	
Sample Date		Client Info		27 Oct 2023	03 Jun 2022	
Machine Age	hrs	Client Info		28821	17715	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	Changed	
Sample Status				NORMAL	SEVERE	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	7	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	0	3	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	6	1	
Tin	ppm	ASTM D5185m	>10	<1	<u>12</u>	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	0	5	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		0	463	
Zinc	ppm	ASTM D5185m		0	2	
Sulfur	ppm	ASTM D5185m		11760	318	
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	
Sodium	ppm	ASTM D5185m		0	3	
Potassium	ppm	ASTM D5185m	>20	0	1	
Water	%	ASTM D6304	>0.05	0.006	0.041	
ppm Water	ppm	ASTM D6304	>500	62.7	417.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1591	3478	
Particles >6µm		ASTM D7647	>1300	339	765	
Particles >14μm		ASTM D7647	>80	26	57	
Particles >21µm		ASTM D7647	>20	11	12	
Particles >38µm		ASTM D7647	>4	1	1	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	19/17/13	
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	ma K∩U/a	VSTM D804E	0.4	0.37	4 179	

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

4.179

0.37



OIL ANALYSIS REPORT





Certificate L2367

Lab Number **Unique Number**

: 06012413 : 10751557

Diagnosed

: 21 Nov 2023 Diagnostician : Doug Bogart

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CAMERON, TX US 76520 Contact: M. FEGGESTAD

mfeggestad@charlottepipe.com

T: F: