


PROBLEM SUMMARY

KAESER SM 10 4962841 (S/N 1521)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Copper	ppm	ASTM D5185m	>50	<u> </u>	20	28	
Debris	scalar	*Visual	NONE	A HEAVY	VLITE	LIGHT	


Customer Id: GRALOU Sample No.: KCPA007515 Lab Number: 06012419 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMEND	ED ACTIONS			
Action	Status	Date	Done By	D
Alert			?	W pa

Description

We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS



30 Aug 2019 Diag: Doug Bogart

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



22 May 2018 Diag: Jonathan Hester



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Machine Id KAESER SM 10 4962841 (S/N 1521) Component

Compressor Fluic

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

A Wear


The copper level is abnormal. All other component wear rates are normal.

Contamination

High concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007515	KCP23728	KCP06490
Sample Date		Client Info		05 Oct 2023	30 Aug 2019	22 May 2018
Machine Age	hrs	Client Info		18769	10834	8041
Oil Age	hrs	Client Info		0	2800	3000
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
		ASTM D5185m				
Iron	ppm		>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	<u>▲</u> 124	20	28
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m			0	2
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	0	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	<1	<1
Zinc	ppm	ASTM D5185m	0	0	18	<1
Sulfur	ppm	ASTM D5185m	23500	11120	14145	7056
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	7	4	8
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>0.05	0.004	0.008	0.011
ppm Water	ppm	ASTM D6304	>500	45.4	89.0	110
FLUID CLEANLIN						
Particles >4µm	ESS	method	limit/base	current	history1	history2
	ESS	method ASTM D7647	limit/base	current	history1 11851	history2 2923
Particles >6µm	ESS					
Particles >6µm	ESS	ASTM D7647	>1300		11851	2923
Particles >6µm Particles >14µm	ESS	ASTM D7647 ASTM D7647	>1300 >80		11851 2 004	2923
Particles >6μm Particles >14μm Particles >21μm	ESS	ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20	 	11851 2004 188	2923 1592 271
Particles >6μm Particles >14μm Particles >21μm Particles >38μm	ESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4	 	11851 2004 188 78	2923 1592 271 91
Particles >6µm Particles >14µm Particles >21µm	ESS	ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647	>1300 >80 >20 >4	 	11851 ▲ 2004 ▲ 188 ▲ 78 ▲ 8	2923 ▲ 1592 ▲ 271 ▲ 91 ▲ 14


Acid Number (AN)


mg KOH/g ASTM D8045 1.0


0.34 0.456 0.415 Contact/Location: Service Manager - GRALOU



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	🔺 HEAVY	VLITE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	45.7	43.7	43.85
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color						

Bottom



Contact/Location: Service Manager - GRALOU