

## **OIL ANALYSIS REPORT**

#### Area PNEUTECH PG 46 [265224] Machine Id PNEUTECH AK100015687 - LARSEN MFG Component

Compressor

{not provided} (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



NORMAL

SAMPLE INFORM	ΛΑΤΙΟΝ	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000041		
Sample Date		Client Info		02 Nov 2023		
Machine Age	hrs	Client Info		3807		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		1		
Phosphorus	ppm	ASTM D5185m		196		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		185		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.28		



# **OIL ANALYSIS REPORT**

VISUAL

Acid Number





					J	<b>,</b>			
White Metal	scalar	*Visual	NONE	NONE					
Yellow Metal	scalar	*Visual	NONE	NONE					
Precipitate		*Visual	NONE	NONE					
Silt	scalar	*Visual	NONE	NONE					
Debris		*Visual	NONE	NONE					
Sand/Dirt		*Visual	NONE	NONE					
Appearance		*Visual	NORML	NORML					
			NORML	-					
Odor		*Visual		NORML					
Emulsified Water		*Visual	>0.1	NEG					
Free Water	scalar	*Visual		NEG					
FLUID PROPERT	IES	method	limit/base	current	history1	history2			
Visc @ 40°C	cSt	ASTM D445		46.5					
SAMPLE IMAGES	3	method	limit/base	current	history1	history2			
Color					no image	no image			
Bottom					no image	no image			
c c nickel			Nov2/23						
Non-ferrous Metals	5		Nov2/23						
Viscosity @ 40°C				Acid Number					
55 50 40 45 40 <b>Abnormal</b> 35 50 <b>Abnormal</b> 35			Nov2/23 Acid Number (mg K0H/g) 10 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0			Nov2Z3			
: 06012500	Received Diagnose Diagnostic	: 20 f d : 22 f cian : Dor 00-237-1369	Nov 2023 Nov 2023 n Baldridge		FLUID-AIRE DYNAMICS 550 ALBION AVE SCHAUMBURG, IL US 60193 Contact: ED DIENER ed.diener@fluidairedynamics.com T: (847)678-8388				



**Unique Number Test Package** Certificate L2367 To discuss this sample report, c \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Laboratory

Sample No. Lab Number

Contact/Location: ED DIENER - UCFLUSCH

F: