




# PROBLEM SUMMARY



Area  
**OKLAHOMA/102/EG - DOZER**  
 Machine Id  
**35.103L [OKLAHOMA^102^EG - DOZER]**  
 Component  
**Hydraulic System**  
 Fluid  
**MOBIL MOBILTRANS AST 30 (8 GAL)**

Sample Rating Trend




ISO



## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

| Sample Status   |                        | ABNORMAL   | NORMAL   | NORMAL   |
|-----------------|------------------------|------------|----------|----------|
| Particles >6µm  | ASTM D7647 >2500       | ▲ 10306    | 1639     | 1544     |
| Oil Cleanliness | ISO 4406 (c) >--/18/16 | ▲ 22/21/16 | 20/18/14 | 20/18/14 |

Customer Id: SHEWIC  
 Sample No.: WC0873939  
 Lab Number: 06013233  
 Test Package: CONST



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Wes Davis +1 905-569-8600 x223  
[wesd@wearcheck.ca](mailto:wesd@wearcheck.ca)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

RECOMMENDED ACTIONS

| Action   | Status | Date | Done By | Description   |
|----------|--------|------|---------|---|
| Resample | ---    | ---  | ?       | We recommend an early resample to monitor this condition. |

HISTORICAL DIAGNOSIS

01 Sep 2023 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



20 Feb 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



01 Nov 2021 Diag: Don Baldrige

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**OKLAHOMA/102/EG - DOZER**  
 Machine Id  
**35.103L [OKLAHOMA^102^EG - DOZER]**  
 Component  
**Hydraulic System**  
 Fluid  
**MOBIL MOBILTRANS AST 30 (8 GAL)**

## DIAGNOSIS

### Recommendation

The filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness is above the acceptable limit for the target ISO 4406 cleanliness code.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

## SAMPLE INFORMATION

|               | method      | limit/base  | current            | history1    | history2    |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info |             | <b>WC0873939</b>   | WC0848937   | WC0778272   |
| Sample Date   | Client Info |             | <b>31 Oct 2023</b> | 01 Sep 2023 | 20 Feb 2023 |
| Machine Age   | hrs         | Client Info | <b>4948</b>        | 4880        | 4414        |
| Oil Age       | hrs         | Client Info | <b>500</b>         | 500         | 474         |
| Oil Changed   | Client Info |             | <b>Not Chngd</b>   | Not Chngd   | Not Chngd   |
| Sample Status |             |             | <b>ABNORMAL</b>    | NORMAL      | NORMAL      |

## CONTAMINATION

|       | method    | limit/base | current    | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >0.1       | <b>NEG</b> | NEG      | NEG      |

## WEAR METALS

|          | method | limit/base  | current | history1     | history2 |     |
|----------|--------|-------------|---------|--------------|----------|-----|
| Iron     | ppm    | ASTM D5185m | >20     | <b>13</b>    | 5        | 3   |
| Chromium | ppm    | ASTM D5185m | >10     | <b>0</b>     | 0        | 0   |
| Nickel   | ppm    | ASTM D5185m | >10     | <b>&lt;1</b> | 0        | 0   |
| Titanium | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0   |
| Silver   | ppm    | ASTM D5185m |         | <b>&lt;1</b> | 0        | 0   |
| Aluminum | ppm    | ASTM D5185m | >10     | <b>2</b>     | 4        | 2   |
| Lead     | ppm    | ASTM D5185m | >10     | <b>&lt;1</b> | 2        | 1   |
| Copper   | ppm    | ASTM D5185m | >75     | <b>&lt;1</b> | 6        | 4   |
| Tin      | ppm    | ASTM D5185m | >10     | <b>&lt;1</b> | <1       | 0   |
| Antimony | ppm    | ASTM D5185m |         | <b>---</b>   | ---      | --- |
| Vanadium | ppm    | ASTM D5185m |         | <b>0</b>     | <1       | 0   |
| Cadmium  | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0   |

## ADDITIVES

|            | method | limit/base  | current | history1     | history2 |      |
|------------|--------|-------------|---------|--------------|----------|------|
| Boron      | ppm    | ASTM D5185m |         | <b>28</b>    | 26       | 22   |
| Barium     | ppm    | ASTM D5185m |         | <b>0</b>     | 0        | 0    |
| Molybdenum | ppm    | ASTM D5185m |         | <b>0</b>     | 2        | 3    |
| Manganese  | ppm    | ASTM D5185m |         | <b>&lt;1</b> | <1       | <1   |
| Magnesium  | ppm    | ASTM D5185m |         | <b>15</b>    | 49       | 47   |
| Calcium    | ppm    | ASTM D5185m |         | <b>2897</b>  | 2884     | 2536 |
| Phosphorus | ppm    | ASTM D5185m |         | <b>1048</b>  | 984      | 849  |
| Zinc       | ppm    | ASTM D5185m |         | <b>1262</b>  | 1261     | 1048 |
| Sulfur     | ppm    | ASTM D5185m |         | <b>5609</b>  | 4844     | 3861 |

## CONTAMINANTS

|           | method | limit/base  | current | history1 | history2 |   |
|-----------|--------|-------------|---------|----------|----------|---|
| Silicon   | ppm    | ASTM D5185m | >20     | <b>5</b> | 10       | 9 |
| Sodium    | ppm    | ASTM D5185m |         | <b>2</b> | 4        | 3 |
| Potassium | ppm    | ASTM D5185m | >20     | <b>0</b> | 0        | 0 |


## FLUID CLEANLINESS

|                 | method       | limit/base | current           | history1 | history2 |
|-----------------|--------------|------------|-------------------|----------|----------|
| Particles >4µm  | ASTM D7647   |            | <b>36666</b>      | 6430     | 6921     |
| Particles >6µm  | ASTM D7647   | >2500      | <b>▲ 10306</b>    | 1639     | 1544     |
| Particles >14µm | ASTM D7647   | >640       | <b>537</b>        | 136      | 107      |
| Particles >21µm | ASTM D7647   | >160       | <b>115</b>        | 38       | 14       |
| Particles >38µm | ASTM D7647   | >40        | <b>3</b>          | 1        | 0        |
| Particles >71µm | ASTM D7647   | >10        | <b>0</b>          | 0        | 0        |
| Oil Cleanliness | ISO 4406 (c) | >--/18/16  | <b>▲ 22/21/16</b> | 20/18/14 | 20/18/14 |




# OIL ANALYSIS REPORT


## Particle Trend




## Particle Trend



## Acid Number



## Viscosity @ 40°C



| FLUID DEGRADATION |          | method     | limit/base | current     | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN)  | mg KOH/g | ASTM D8045 |            | <b>1.02</b> | 1.25     | 1.03     |

| VISUAL           |        | method  | limit/base | current      | history1 | history2 |
|------------------|--------|---------|------------|--------------|----------|----------|
| White Metal      | scalar | *Visual | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Precipitate      | scalar | *Visual | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Silt             | scalar | *Visual | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Debris           | scalar | *Visual | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Sand/Dirt        | scalar | *Visual | NONE       | <b>NONE</b>  | NONE     | NONE     |
| Appearance       | scalar | *Visual | NORML      | <b>NORML</b> | NORML    | NORML    |
| Odor             | scalar | *Visual | NORML      | <b>NORML</b> | NORML    | NORML    |
| Emulsified Water | scalar | *Visual | >0.1       | <b>NEG</b>   | NEG      | NEG      |
| Free Water       | scalar | *Visual |            | <b>NEG</b>   | NEG      | NEG      |


| FLUID PROPERTIES |     | method    | limit/base | current     | history1 | history2 |
|------------------|-----|-----------|------------|-------------|----------|----------|
| Visc @ 40°C      | cSt | ASTM D445 | 57.6       | <b>98.8</b> | 96.0     | 96.3     |

| SAMPLE IMAGES |  | method | limit/base | current | history1 | history2 |
|---------------|--|--------|------------|---------|----------|----------|
|---------------|--|--------|------------|---------|----------|----------|

Color




Bottom




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0873939  
 Lab Number : 06013233  
 Unique Number : 10752377  
 Test Package : CONST

**SHERWOOD CONSTRUCTION CO INC**  
 3219 WEST MAY ST  
 WICHITA, KS  
 US 67213  
 Contact: DOUG KING  
 doug.king@sherwood.net  
 T: (316)617-3161  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)