




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**AVURE M1 HPU2**  
 Component  
**Hydraulic System**  
 Fluid  
**STARFIRE AW 32 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0842447</b>	WC0842443	WC0842442
Sample Date	Client Info			<b>15 Nov 2023</b>	18 Oct 2023	15 Sep 2023
Machine Age	yrs	Client Info		<b>4</b>	4	4
Oil Age	yrs	Client Info		<b>1</b>	1	1
Oil Changed	Client Info			<b>Filtered</b>	Not Changd	Filtered
Sample Status				<b>NORMAL</b>	NORMAL	ATTENTION

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.05	<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<b>2</b>	2	7
Chromium	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Lead	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m	>20	<b>12</b>	10	11
Tin	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	3	1
Calcium	ppm	ASTM D5185m		<b>7</b>	8	6
Phosphorus	ppm	ASTM D5185m		<b>280</b>	287	247
Zinc	ppm	ASTM D5185m		<b>221</b>	264	198
Sulfur	ppm	ASTM D5185m		<b>1197</b>	1256	1153





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<b>1</b>	1	2
Sodium	ppm	ASTM D5185m		<b>3</b>	1	<1
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<b>1341</b>	830	▲ 6510
Particles >6µm		ASTM D7647	>1300	<b>246</b>	177	335
Particles >14µm		ASTM D7647	>160	<b>20</b>	14	20
Particles >21µm		ASTM D7647	>40	<b>7</b>	4	6
Particles >38µm		ASTM D7647	>10	<b>0</b>	0	1
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	1
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<b>18/15/11</b>	17/15/11	▲ 20/16/11

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.31</b>	0.39	0.35




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	30.3	30.2	29.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0842447 Received : 20 Nov 2023  
 Lab Number : 06013248 Diagnosed : 22 Nov 2023  
 Unique Number : 10752392 Diagnostician : Don Baldrige  
 Test Package : IND 2

**UNIVERSAL PURE**  
 1571 GRESSEL DR  
 DELPHOS, OH  
 US 45833  
 Contact: K BRONSON  
 kbronson@universalpure.com  
 T: (419)551-6185  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)