



## **PROBLEM SUMMARY**



#### Machine Id 5303552 (S/N 1059) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

### COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

THOBELM/THO TE	OTTILOOLIO		
Sample Status		ABNORMAL	 
Particles >6µm	ASTM D7647 >1	1300 🔺 <b>41960</b>	 
Particles >14µm	ASTM D7647 >8	30 <b>A 2862</b>	 
Particles >21µm	ASTM D7647 >2	20 <b>A 563</b>	 
Particles >38µm	ASTM D7647 >4	4 🔺 10	 
Oil Cleanliness	ISO 4406 (c) >-	-/17/13 🔺 24/23/19	 

Customer Id: SSFPLA Sample No.: KCPA009265 Lab Number: 06013287 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

*To change component or sample information:* Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u> There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS



## **OIL ANALYSIS REPORT**



ISO

Machine Id 5303552 (S/N 1059) Component

Compressor

Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

#### DIAGNOSIS

#### A Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA009265		
Sample Date		Client Info		13 Nov 2023		
Machine Age	hrs	Client Info		44677		
Dil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m		0		
Lead	ppm	ASTM D5185m	>10	0		
		ASTM D5185m		0		
Copper Tin	ppm	ASTM D5185m	>50 >10	ں <1		
	ppm		>10			
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	100	2		
Calcium	ppm	ASTM D5185m	0	1		
Phosphorus	ppm	ASTM D5185m	0	476		
Zinc	ppm	ASTM D5185m		27		
Sulfur	ppm	ASTM D5185m	23500	585		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		<1		
Sodium	ppm	ASTM D5185m	220	<1		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D5185III	- =0	0.003		
ppm Water	ppm	ASTM D0304 ASTM D6304	>500	37.7		
				51.1		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		112606		
Particles >6µm		ASTM D7647		<u> </u>		
Particles >14µm		ASTM D7647	>80	<u> </u>		
		ASTM D7647	>20	<u> </u>		
Particles >21µm		ASTM D7647	>4	<u> </u>		
Particles >21µm		AGTIVI D7047				
Particles >14μm Particles >21μm Particles >38μm Particles >71μm		ASTM D7647	>3	1		
Particles >21µm Particles >38µm			>3 >/17/13	1 ▲ 24/23/19		
Particles >21µm Particles >38µm Particles >71µm		ASTM D7647				



# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
/hite Metal	scalar	*Visual	NONE	NONE		
ellow Metal	scalar	*Visual	NONE	NONE		
recipitate	scalar	*Visual	NONE	NONE		
lt	scalar	*Visual	NONE	NONE		
ebris	scalar	*Visual	NONE	LIGHT		
and/Dirt	scalar	*Visual	NONE	NONE		
opearance	scalar	*Visual	NORML	NORML		
dor	scalar	*Visual	NORML	NORML		
nulsified Water	scalar	*Visual	>0.05	NEG		
ee Water	scalar	*Visual		NEG		
FLUID PROPERT	TIES	method	limit/base	current	history1	history2
sc @ 40°C	cSt	ASTM D445	45	48.2		
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
olor					no image	no image
ottom					no image	no image
GRAPHS						
Ferrous Alloys				Particle Count	:	1.0
iron			491,520	I		1 <sup>26</sup>
chromium			122,880			-24
			30,720			
						-22
			7,680		\	-20
3,23						-20
						+20 +18
	s					-20 -18 -16
	s					-20 -18 -16 -14
Non-ferrous Metal	s		Nov13/23			-18 -16 -14
Non-ferrous Metal	S					-18 -16 -14
Non-ferrous Metal	S		CZCELNON 1,920 1,920 1,920 480 120 120 30			-18 -16 -14
Non-ferrous Metal	S		ECCE LAND 480 120 120 120 30 8	Bibresemal		-18 -16 -14 -12
Copper lead	S		ECCE LAND 480 120 120 120 30 8			-18 -16 -14 -12
Non-ferrous Metal	S		CZ/ELV CZ/ELV CZ/ELV CZ/ELV CZ/ELV CZ/ELV	<b>Biorese</b> mal	140 210	-18 16 -14 -12 -10 -8 -8 -8
Non-ferrous Metal	S		FEZEELAND 1.920   480 120   30 30   8 8   627E1volv 0   480 480	<b>Biorese</b> mal	14μ 21μ	-18 -16 -14 -12
Viscosity @ 40°C	S		FEZEELAND 1.920   480 120   30 30   8 8   627E1volv 0   480 480	Rbræmal u 6ju	14μ 21μ	-18 16 -14 -12 -10 -8 -8 -8
Viscosity @ 40°C	S		FEZEELAND 1.920   480 120   30 30   8 8   627E1volv 0   480 480	<b>βόσσe</b> mal μ 6μ Acid Number	14μ 21μ	-18 16 -14 -12 -10 -8 -8 -8
Non-ferrous Metal	S		FEZ/ELANON 1.920   480 120   30 30   8 2   62/ELANON 0   480 480	<b>βόσσe</b> mal μ 6μ Acid Number	14μ 21μ	-18 16 -14 -12 -10 -8 -8 -8
Non-ferrous Metal	S		FEZ/ELANON 1.920   480 120   30 30   8 2   62/ELANON 0   480 480	<b>βόσσe</b> mal μ 6μ Acid Number	14μ 21μ	-18 16 -14 -12 -10 -8 -8 -8
Non-ferrous Metal	S		(Im 1.920   (EZEELANDY 480   120 30   30 8   60/10,0.96 0,0.96   90,0.96 0,0.96   90,0.97 0,0.46   90,0.24 0.24	<b>βόσσe</b> mal μ 6μ Acid Number	14μ 21μ	-18 16 -14 -12 -10 -8 -8 -8
Viscosity @ 40°C	S		CZCELNON CZCELN	Boresemal Acid Number	14μ 21μ	-18 16 -14 -12 10 -8 -8 $-71\mu$
Non-ferrous Metal	S		(Im 1.920   (EZEELANDY 480   120 30   30 8   60/10,0.96 0,0.96   90,0.96 0,0.96   90,0.97 0,0.46   90,0.24 0.24	<b>βόσσe</b> mal μ 6μ Acid Number	14μ 21μ	-18 16 -14 -12 -10 -8 -8 -8



Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. BRIAN.HERKALO@SSFPRODUCTION.COM \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnosed

: 29 Nov 2023

Diagnostician : Jonathan Hester

: 06013287

US 12901

Т:

F:

PLATTSBURGH, NY

Contact: BRIAN HERKALO