


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



KAESER 7440862

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan2021 N	May2021 Aug2021 Jan20	22 Jun2022 Aug2022 Nov2022	Nov2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006367	KCP47920D	KCP44103
Sample Date		Client Info		08 Nov 2023	07 Nov 2022	08 Aug 2022
Machine Age	hrs	Client Info		9197	5845	5135
Oil Age	hrs	Client Info		0	1000	3000
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	17	39	25
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	76	85	56
Calcium	ppm	ASTM D5185m	0	2	1	0
Phosphorus	ppm	ASTM D5185m	0	1	2	0
Zinc	ppm	ASTM D5185m	0	0	2	2
Sulfur	ppm	ASTM D5185m	23500	18887	22433	19711
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	1
Sodium	ppm	ASTM D5185m		7	6	5
Potassium	ppm	ASTM D5185m	>20	1	0	<1
Water	%	ASTM D6304	>0.05	0.017	0.033	△ 0.200
ppm Water	ppm	ASTM D6304	>500	171.7	334.8	<u>^</u> 2000
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2299	4093	
Particles >6µm		ASTM D7647	>1300	768	<u>1311</u>	
Particles >14μm		ASTM D7647	>80	32	70	
Particles >21µm		ASTM D7647	>20	5	22	
Particles >38μm		ASTM D7647	>4	0	1	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/17/12	1 9/18/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.40

0.32

0.37



OIL ANALYSIS REPORT







Sample No. Lab Number

Unique Number Test Package : IND 2 (Additional Tests: KF, PrtCount)

Received : KCPA006367 : 22 Nov 2023

: 06013318 Diagnosed Diagnostician : Don Baldridge : 10752462

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

BELOIT, WI US 53511

Contact: Service Manager