


PROBLEM SUMMARY

Sample Rating Trend

Machine Id 8190361 (S/N 1281) Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | | | |
|--------------------------|--------------|---------|-----------------|----------|--|--|--|--|--|--|
| Sample Status | | | ATTENTION | ABNORMAL | | | | | | |
| Particles >14µm | ASTM D7647 | >80 | <u> </u> | 41 | | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >/17/13 | 19/17/14 | 21/18/13 | | | | | | |

Customer Id: OCEORL Sample No.: KC106351 Lab Number: 06013326 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

| RECOMMENDED ACTIONS | | | | | | |
|---------------------|--------|------|---------|---|--|--|
| Action | Status | Date | Done By | Description | | |
| Change Fluid | | | ? | Oil and filter change at the time of sampling has been noted. | | |
| Change Filter | | | ? | Oil and filter change at the time of sampling has been noted. | | |

HISTORICAL DIAGNOSIS



21 Oct 2022 Diag: Jonathan Hester

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id 8190361 (S/N 1281) Component

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


| | | | 0ct2022 | Nov2023 | | |
|----------------------------|----------|--------------|------------|-------------------|-------------------|------------|
| SAMPLE INFORM | | method | limit/base | | history1 | history2 |
| | | Client Info | mmubase | KC106351 | KC100447 | Thistory 2 |
| Sample Number | | Client Info | | 07 Nov 2023 | 21 Oct 2022 | |
| Sample Date Machine Age | hrs | Client Info | | 9805 | 5579 | |
| Oil Age | hrs | Client Info | | 9805 | 0 | |
| Oil Changed | 1115 | Client Info | | Changed | Changed | |
| Sample Status | | | | ATTENTION | ABNORMAL | |
| | | | 11 | | | |
| WEAR METALS | | method | limit/base | | history1 | history2 |
| Iron | ppm | ASTM D5185m | >50 | 0 | <1 | |
| Chromium | ppm | ASTM D5185m | | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >3 | <1 | 0 | |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | |
| Silver | ppm | ASTM D5185m | >2 | 0 | <1 | |
| Aluminum | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Lead | ppm | ASTM D5185m | >10 | 0 | <1 | |
| Copper | ppm | ASTM D5185m | >50 | 6 | 11 | |
| Tin | ppm | ASTM D5185m | >10 | <1 | 0 | |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | |
| Barium | ppm | ASTM D5185m | 90 | 0 | 0 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | |
| Magnesium | ppm | ASTM D5185m | 90 | 37 | 32 | |
| Calcium | ppm | ASTM D5185m | 2 | 2 | <1 | |
| Phosphorus | ppm | ASTM D5185m | | 1 | 3 | |
| Zinc | ppm | ASTM D5185m | | 3 | 8 | |
| CONTAMINANTS | 6 | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 0 | 2 | |
| Sodium | ppm | ASTM D5185m | | 12 | 11 | |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 1 | |
| Water | % | ASTM D6304 | >0.05 | 0.018 | 0 .182 | |
| ppm Water | ppm | ASTM D6304 | >500 | 187.9 | ▲ 1820 | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | | 2840 | 13493 | |
| Particles >6µm | | ASTM D7647 | >1300 | 1237 | 1 593 | |
| Particles >14µm | | ASTM D7647 | >80 | <u> </u> | 41 | |
| Particles >21µm | | ASTM D7647 | >20 | 14 | 4 | |
| Particles >38µm | | ASTM D7647 | >4 | 1 | 1 | |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 0 | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | 19/17/14 | 1 21/18/13 | |
| FLUID DEGRADA | ATION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.23 | 0.30 | |
| (-) | 0 - 0 | | | | | |




OIL ANALYSIS REPORT









: Don Baldridge

Certificate 12367 Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 10752470

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

Unique Number

Contact/Location: Service Manager - OCEORL

US 32817

T: F:

Contact: Service Manager