


PROBLEM SUMMARY

KAESER SFC 75S 6654014 (S/N 1531)

Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
Copper	ppm	ASTM D5185m	>50	<u> </u>	▲ 69	1 92	


Customer Id: HUTPLYKC Sample No.: KC124628 Lab Number: 06013329 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

17 Jan 2023 Diag: Don Baldridge


No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted.

Resample at the next service interval to monitor. The copper level has decreased, but is still abnormal. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

12 Sep 2022 Diag: Angela Borella

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

30 Mar 2022 Diag: Doug Bogart







view report

view repor





OIL ANALYSIS REPORT

KAESER SFC 75S 6654014 (S/N 1531)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

🔺 Wear


The copper level is abnormal. All other component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124628	KC96352	KC85626
Sample Date		Client Info		06 Nov 2023	17 Jan 2023	12 Sep 2022
Machine Age	hrs	Client Info		41717	35883	32834
Oil Age	hrs	Client Info		0	7029	3980
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		175	<u> </u>	1 92
Tin	ppm	ASTM D5185m		<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron		ASTM D5185m			0	0
	ppm	ASTM D5185m	00	0	1	<1
Barium	ppm		90	0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m	00	-	÷	0
Magnesium	ppm	ASTM D5185m	90	<1 1	<1	0
Calcium	ppm	ASTM D5185m	2	1	0	4
Phosphorus	ppm	ASTM D5185m		0	4	4
Zinc	ppm	ASTM D5185m		U	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.05	0.005	0.004	0.005
ppm Water	ppm	ASTM D6304	>500	56.9	44.8	58.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2600	1268	2451
Particles >6µm		ASTM D7647	>1300	753	261	594
Particles >14µm		ASTM D7647	>80	58	18	20
Particles >21µm		ASTM D7647	>20	16	5	2
Particles >38µm		ASTM D7647	>4	1	0	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	17/15/11	18/16/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.25	0.36



OIL ANALYSIS REPORT







3


Ē

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.8	43.1	43.4
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color



Bottom



Contact/Location: SERVICE MANAGER ? - HUTPLYKC