




PROBLEM SUMMARY

Sample Rating Trend



WATER





Machine Id
KAESER ASD 25 6946811 (S/N 1069)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	NORMAL
Water	%	ASTM D6304	>0.05	▲ 0.191	0.026	0.014
ppm Water	ppm	ASTM D6304	>500	▲ 1910	267.2	144.4
Particles >6µm		ASTM D7647	>1300	▲ 137078	▲ 9802	625
Particles >14µm		ASTM D7647	>80	▲ 4472	▲ 238	24
Particles >21µm		ASTM D7647	>20	▲ 267	▲ 40	6
Particles >38µm		ASTM D7647	>4	▲ 11	4	0
Particles >71µm		ASTM D7647	>3	▲ 2	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ 25/24/19	▲ 24/20/15	16/12

Customer Id: PAPWAS
 Sample No.: KCPA009406
 Lab Number: 06013353
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

07 Nov 2022 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



11 Jan 2021 Diag: Doug Bogart

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
KAESER ASD 25 6946811 (S/N 1069)

Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)



DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KCPA009406	KCP47191	KCP27231
Sample Date	Client Info	07 Nov 2023	07 Nov 2022	11 Jan 2021
Machine Age	hrs	4266	4996	523
Oil Age	hrs	0	4473	523
Oil Changed	Client Info	N/A	Changed	Changed
Sample Status		ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	<1	1	3
Chromium	ppm ASTM D5185m >10	0	0	0
Nickel	ppm ASTM D5185m >3	<1	0	<1
Titanium	ppm ASTM D5185m >3	0	0	0
Silver	ppm ASTM D5185m >2	0	0	0
Aluminum	ppm ASTM D5185m >10	4	2	8
Lead	ppm ASTM D5185m >10	0	0	<1
Copper	ppm ASTM D5185m >50	11	7	<1
Tin	ppm ASTM D5185m >10	<1	0	<1
Antimony	ppm ASTM D5185m	---	---	0
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	0	0	10
Barium	ppm ASTM D5185m 90	<1	0	0
Molybdenum	ppm ASTM D5185m 0	0	0	<1
Manganese	ppm ASTM D5185m	<1	<1	<1
Magnesium	ppm ASTM D5185m 100	7	5	66
Calcium	ppm ASTM D5185m 0	2	0	2
Phosphorus	ppm ASTM D5185m 0	1	1	18
Zinc	ppm ASTM D5185m 0	164	100	21
Sulfur	ppm ASTM D5185m 23500	17840	21357	16817

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	<1	1	<1
Sodium	ppm ASTM D5185m	2	9	10
Potassium	ppm ASTM D5185m >20	<1	2	53
Water	% ASTM D6304 >0.05	▲ 0.191	0.026	0.014
ppm Water	ppm ASTM D6304 >500	▲ 1910	267.2	144.4






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	271288	81426	1555
Particles >6µm	ASTM D7647 >1300	▲ 137078	▲ 9802	625
Particles >14µm	ASTM D7647 >80	▲ 4472	▲ 238	24
Particles >21µm	ASTM D7647 >20	▲ 267	▲ 40	6
Particles >38µm	ASTM D7647 >4	▲ 11	4	0
Particles >71µm	ASTM D7647 >3	▲ 2	0	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 25/24/19	▲ 24/20/15	16/12

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 1.0	0.38	0.44	0.268


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	45	48.4	45.9	44.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA009406 **Received** : 20 Nov 2023
Lab Number : 06013353 **Diagnosed** : 29 Nov 2023
Unique Number : 10752497 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

PAPER PAK
 184 PAPER PAK PKWY
 WASHINGTON, GA
 US 30673
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: