

PROBLEM SUMMARY

ROBERT W TAYLOR

[ROBERT W TAYLOR] 004 568680-4


Component
Port Reduction Gear

SHELL ROTELLA T 40 (--- GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	NORMAL		
Copper	ppm	ASTM D5185m	>50	A 78	△ 50	21		

Customer Id: INGPAD Sample No.: MW0061507 Lab Number: 06013409 Test Package: MAR 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

02 Oct 2023 Diag: Jonathan Hester

WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



07 May 2023 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Mar 2020 Diag: Wes Davis

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

ROBERT W TAYLOR [ROBERT W TAYLOR] 004 568680-4

Port Reduction Gear

SHELL ROTELLA T 40 (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		MW0061507	MW0046462	MW0046412
Sample Date		Client Info		04 Nov 2023	02 Oct 2023	07 May 2023
Machine Age	hrs	Client Info		16081	15902	14176
Oil Age	hrs	Client Info		755	577	382
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	3	6	6
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>10	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		<1	<1	0
Aluminum	ppm	ASTM D5185m	>25	1	1	0
Lead	ppm	ASTM D5185m	>100	<1	1	0
Copper	ppm	ASTM D5185m	>50	<u>^</u> 78	△ 50	21
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m	>5			
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	40	44	96
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m	0	97	95	74
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	432	47	29	28
Calcium	ppm	ASTM D5185m	1121	2590	2593	2526
Phosphorus	ppm	ASTM D5185m	996	1028	1025	946
Zinc	ppm	ASTM D5185m	881	1133	1261	1073
Sulfur	ppm	ASTM D5185m		3242	3767	4525
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2	3	4
Sodium	ppm	ASTM D5185m		<1	2	2
Potassium	ppm	ASTM D5185m	>20	0	<1	0
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.02	1.34	1.31



OIL ANALYSIS REPORT





2.00	d Nur	nber							
Acid Number (mg KOH/g)	~	V	\sim	^	1	M	Ψ	V	Λ
Jun23/10	Jan23/12	Jul9/13 +	0ct17/13 -	Jun4/15	0ct7/15	Mar26/16 -	Aug10/16 -	Apr22/19	Nov4/23


FLUID PROPER	RIIES	method	iimit/base	current	nistory i	nistor
Visc @ 40°C	cSt	ASTM D445	142.1	120	121	120

limit/base

current

no image

method




Bottom no image no image no image


GRAPHS


Color


Ferrous Alloys

SAMPLE IMAGES









history1

no image

history2

no image





Certificate L2367

Laboratory Test Package

Sample No. Lab Number **Unique Number**

: MW0061507 : 06013409 : 10752553 : MAR 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed Diagnostician

: 20 Nov 2023 : 23 Nov 2023 : Don Baldridge **INGRAM BARGE** 900 S 3RD ST PADUCAH, KY

US 42003 Contact: KEN ELLISON

F: (615)695-3697

ken.ellison@ingrambarge.com T: (270)415-4467

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)