


# PROBLEM SUMMARY

Sample Rating Trend





**WATER**



Area  
**Thermoforming**  
Machine Id  
**Line 12 B Extruder (S/N 46270220-10300-1)**  
Component  
**Bevel Helical Gearbox**  
Fluid  
**MOBIL SHC 632 (21 GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check for the source of water entry. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Silicon	ppm	ASTM D5185m	>50	▲ <b>97</b>	26	14
Water	%	ASTM D6304	>0.1	▲ <b>0.808</b>	▲ 0.810	▲ 0.425
ppm Water	ppm	ASTM D6304	>1000	▲ <b>8080</b>	▲ 8100	▲ 4250
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	▲ HAZY	▲ HAZY
Viscosity Index (VI)	Scale	ASTM D2270	169	▲ <b>137</b>	161	142

Customer Id: DARDALTX  
Sample No.: TO50001927  
Lab Number: 06014032  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Check Water Access	---	---	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

### 17 Oct 2023 Diag: Jonathan Hester

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a high amount of particulates present in the oil. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 14 Nov 2022 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

view report



### 10 Oct 2022 Diag: Jonathan Hester

WATER




We suspect abnormal contamination may be due to sampling method. We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. High concentration of visible metal present. All component wear rates are normal. Appearance is hazy. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

view report



Area  
**Thermoforming**  
 Machine Id  
**Line 12 B Extruder (S/N 46270220-10300-1)**  
 Component  
**Bevel Helical Gearbox**  
 Fluid  
**MOBIL SHC 632 (21 GAL)**



**DIAGNOSIS**

**Recommendation**  
 We advise that you check for the source of water entry. Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 Appearance is hazy. There is a high concentration of water present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

**Fluid Condition**  
 The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO50001927</b>	TO50001607	TO50001209
Sample Date	Client Info		<b>16 Nov 2023</b>	17 Oct 2023	14 Nov 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>Not Chngd</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>4</b>	34	126
Iron	ppm	ASTM D5185m >150	<b>6</b>	6	104
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	2
Aluminum	ppm	ASTM D5185m >25	<b>2</b>	<1	<1
Lead	ppm	ASTM D5185m >100	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	<1
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0






ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Calcium	ppm	ASTM D5185m	<b>2</b>	5	1
Phosphorus	ppm	ASTM D5185m	<b>446</b>	481	413
Zinc	ppm	ASTM D5185m	<b>0</b>	0	<1
Sulfur	ppm	ASTM D5185m	<b>151</b>	32	124

CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>▲ 97</b>	26	14
Sodium	ppm	ASTM D5185m	<b>1</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>1</b>	<1	2
Water	%	ASTM D6304 >0.1	<b>▲ 0.808</b>	▲ 0.810	▲ 0.425
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 8080</b>	▲ 8100	▲ 4250

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>1300	---	▲ 4533	---
Particles >6µm	ASTM D7647	>320	---	▲ 2469	---
Particles >14µm	ASTM D7647	>80	---	▲ 420	---
Particles >21µm	ASTM D7647	>20	---	▲ 142	---
Particles >38µm	ASTM D7647	>4	---	▲ 22	---
Particles >71µm	ASTM D7647	>3	---	▲ 2	---
Oil Cleanliness	ISO 4406 (c)	>17/15/13	---	▲ 19/18/16	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	---	0.47	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	MODER	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	HAZY	HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	325.8	335	347
Visc @ 100°C	cSt	ASTM D445	38.6	32.6	31.2
Viscosity Index (VI)	Scale	ASTM D2270	169	137	142

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO50001927 **Received** : 21 Nov 2023  
**Lab Number** : 06014032 **Diagnosed** : 27 Nov 2023  
**Unique Number** : 10753176 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PQ, PrtCount, VI )

**DART CONTAINER CORPORATION**  
 4444 W LEADBETTER DR  
 DALLAS, TX  
 US 75236  
 Contact: YON PALOMINO  
 yon.palomino@dart.biz  
 T: (214)775-5673  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)