


PROBLEM SUMMARY

Area
Wax Cups
 Machine Id
POS 49
 Component
Unknown Component
 Fluid
TULCO LUBSOIL INDUSTRIAL GEAR OIL 150 (--- GAL)

Sample Rating Trend



SEDIMENT



COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	---
Silt	scalar	*Visual	NONE	▲ MODER	NONE	---
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML	---

Customer Id: DARDALTX
Sample No.: TO50001527
Lab Number: 06014036
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

30 Mar 2023 Diag: Doug Bogart

DIRT




We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the sample. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the sample is suitable for further service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Area
Wax Cups
 Machine Id
POS 49
 Component
Unknown Component
 Fluid
TULCO LUBSOIL INDUSTRIAL GEAR OIL 150 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the sample is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50001527	TO50001571	---
Sample Date	Client Info	16 Nov 2023	30 Mar 2023	---
Machine Age	hrs	0	0	---
Oil Age	hrs	0	0	---
Oil Changed	Client Info	Not Changed	N/A	---
Sample Status		ABNORMAL	ABNORMAL	---

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	15	21	---
Iron	ppm	36	37	---
Chromium	ppm	<1	0	---
Nickel	ppm	3	0	---
Titanium	ppm	<1	<1	---
Silver	ppm	0	0	---
Aluminum	ppm	2	<1	---
Lead	ppm	2	2	---
Copper	ppm	4	5	---
Tin	ppm	<1	0	---
Vanadium	ppm	0	0	---
Cadmium	ppm	<1	<1	---

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m	13	10	0	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		<1	0	---
Manganese	ppm	ASTM D5185m		<1	1	---
Magnesium	ppm	ASTM D5185m		1	10	---
Calcium	ppm	ASTM D5185m		5	9	---
Phosphorus	ppm	ASTM D5185m	170	272	225	---
Zinc	ppm	ASTM D5185m		3	16	---
Sulfur	ppm	ASTM D5185m	6300	6459	6657	---

CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m		2411	▲ 695	---
Sodium	ppm	ASTM D5185m		4	7	---
Potassium	ppm	ASTM D5185m	>20	2	2	---
Water	%	ASTM D6304		0.017	0.001	---
ppm Water	ppm	ASTM D6304		174	11.9	---






FLUID CLEANLINESS

method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	>5000	---	▲ 156801	---
Particles >6µm	ASTM D7647	>1300	---	▲ 32667	---
Particles >14µm	ASTM D7647	>160	---	▲ 454	---
Particles >21µm	ASTM D7647	>40	---	▲ 64	---
Particles >38µm	ASTM D7647	>10	---	1	---
Particles >71µm	ASTM D7647	>3	---	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	---	▲ 24/22/16	---

FLUID DEGRADATION

method	limit/base	current	history1	history2		
Acid Number (AN)	mg KOH/g	ASTM D8045		0.50	0.52	---


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	LIGHT	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	NONE	---
Debris	scalar	*Visual	NONE	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	NEG	NEG	---	---
Free Water	scalar	*Visual	NEG	NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	148	179.2	163	---
Visc @ 100°C	cSt	ASTM D445	14.5	17.5	15.2	---
Viscosity Index (VI)	Scale	ASTM D2270	96	105	93	---

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001527 **Received** : 21 Nov 2023
Lab Number : 06014036 **Diagnosed** : 30 Nov 2023
Unique Number : 10753180 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)