

PROBLEM SUMMARY


Sample Rating Trend

SEDIMENT

Paper Cup Machines PMC 1001 POS-125 (S/N 50299)

Circulating System

SUMMIT Syngear SH-1032 320 (85 GAL)





COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL					
Silt	scalar	*Visual	NONE	▲ MODER	NONE	▲ HEAVY					
Appearance	scalar	*Visual	NORML	HAZY	NORML	▲ HAZY					

Customer Id: DARDALTX Sample No.: TO50001752 Lab Number: 06014037 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

27 Sep 2023 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



25 Aug 2023 Diag: Doug Bogart

SEDIMENT



Resample at the next service interval to monitor. All component wear rates are normal. Appearance is milky. There is a high amount of visible silt present in the sample. The AN level is acceptable for this fluid.



05 Jun 2023 Diag: Don Baldridge

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Appearance is hazy. There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil. Excessive free water present. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend

SEDIMENT

Paper Cup Machines PMC 1001 POS-125 (S/N 50299)

Circulating System

SUMMIT Syngear SH-1032 320 (85 GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

Appearance is hazy. There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO50001752	TO50001167	TO50001782
Sample Date		Client Info		16 Nov 2023	27 Sep 2023	25 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		17	20	23
Iron	ppm	ASTM D5185m		14	15	22
Chromium	ppm	ASTM D5185m		<1	<1	0
Nickel	ppm	ASTM D5185m		9	6	22
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver		ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m		2	<1	3
	ppm					
Lead	ppm	ASTM D5185m		<1	<1	<1
Copper	ppm	ASTM D5185m		2	2	2
Tin	ppm	ASTM D5185m		<1	<1	1
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		<1	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		119	110	135
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		<1	<1	4
Calcium	ppm	ASTM D5185m		4	34	2
Phosphorus	ppm	ASTM D5185m		518	488	514
Zinc	ppm	ASTM D5185m		0	7	<1
Sulfur	ppm	ASTM D5185m		9319	8691	9279
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		7891	3359	10000
Sodium	ppm	ASTM D5185m		<1	2	2
Potassium	ppm	ASTM D5185m	>20	1	1	1
Water	%	ASTM D6304		0.028	0.022	0.022
ppm Water	ppm	ASTM D6304		285	224.3	223.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>1300		<u>▲</u> 85812	
Particles >6µm		ASTM D7647	>320		▲ 7168	
Particles >14µm		ASTM D7647	>80		33	
Particles >21µm		ASTM D7647	>20		6	
Particles >38µm		ASTM D7647	>4		1	
Particles >71μm		ASTM D7647	>3		1	
Oil Cleanliness		ISO 4406 (c)	>17/15/13		<u>4</u> 24/20/12	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045

0.86

0.91



OIL ANALYSIS REPORT







Sample No. Lab Number **Unique Number**

: 06014037 : 10753181

Received Diagnosed

: 24 Nov 2023 Diagnostician : Don Baldridge Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 4444 W LEADBETTER DR DALLAS, TX US 75236

Contact: YON PALOMINO

yon.palomino@dart.biz T: (214)775-5673

F:

Submitted By: YON PALOMINO