

OIL ANALYSIS REPORT


Sample Rating Trend

NORMAL

Refrigeration Compressor VILTER TYSCJ 2VILT (S/N 47081)

Refrigeration Compressor

USPI 1009-68 SC (--- QTS)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	2012 Jun2013 Aug2014 Sep2016 Apr2018 Jan2020 Sep2021 Dec2022						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		USP0003607	USP249544	USP217359	
Sample Date		Client Info		14 Nov 2023	26 Aug 2023	28 Jun 2023	
Machine Age	hrs	Client Info		0	5338	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				NORMAL	NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>8	2	4	0	
Chromium	ppm	ASTM D5185m	>2	<1	0	0	
Nickel	ppm	ASTM D5185m		<1	0	0	
Titanium	ppm	ASTM D5185m		<1	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	<1	<1	
Lead	ppm	ASTM D5185m	>2	0	0	0	
Copper	ppm	ASTM D5185m	>8	<1	0	0	
Tin	ppm	ASTM D5185m	>4	0	0	0	
Vanadium	ppm	ASTM D5185m		0	0	0	
Cadmium	ppm	ASTM D5185m		<1	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m		0	0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	0	
Manganese	ppm	ASTM D5185m		0	0	0	
Magnesium	ppm	ASTM D5185m		0	0	0	
Calcium	ppm	ASTM D5185m		0	0	0	
Phosphorus	ppm	ASTM D5185m		0	0	0	
Zinc	ppm	ASTM D5185m		0	0	0	
Sulfur	ppm	ASTM D5185m	50	0	0	0	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	<1	0	0	
Sodium	ppm	ASTM D5185m	710	0	0	<1	
Potassium	ppm	ASTM D5185m	>20	<1	0	<1	
Water	%	ASTM D6304	>0.01	0.002	0.001	0.002	
ppm Water	ppm	ASTM D6304	>100	19	8.9	15.5	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2	
Particles >4μm		ASTM D7647	>10000	3485	1727	1226	
Particles >6µm		ASTM D7647	>2500	897	351	264	
Particles >14µm		ASTM D7647	>320	24	46	13	
Particles >21µm		ASTM D7647	>80	4	15	4	
Particles >38µm		ASTM D7647	>20	0	0	0	
Particles >71µm		ASTM D7647	>4	0	0	0	
				19/17/12	18/16/13	17/15/11	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/12	10/10/13	17/13/11	
Oil Cleanliness FLUID DEGRADA	TION _	method	limit/base	current	history1	history2	



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number

Unique Number Test Package

: USP0003607

: 06014064 : 10753208 : IND 2

: 21 Nov 2023 Received Diagnosed Diagnostician

: 24 Nov 2023 : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TYSON-Columbus Junction-USP HWY 70 North, P.O. Box 272

Columbus Junction, IA US 52738

Contact: THOMAS SCHREIBER thomas.schreiber@tyson.com

T:

F: (319)753-6235