

OIL ANALYSIS REPORT

Area **LS-500-46** SULLAIR 003-59180 - CHARLOTTE OBSERVER Component

Compressor

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

NORMAL		
•		
	Nov2023	Aug ² 023

Sample Rating Trend




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06014107	UCH05962963	
Sample Date		Client Info		16 Nov 2023	28 Aug 2023	
Machine Age	hrs	Client Info		76961	76680	
Oil Age	hrs	Client Info		4819	4538	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m		<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	2	<1	
Lead	ppm	ASTM D5185m	>25	0	0	
Copper	ppm	ASTM D5185m	>50	1	1	
Tin	ppm	ASTM D5185m	>15	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		<1	0	
Calcium	ppm	ASTM D5185m		2	0	
Phosphorus	ppm	ASTM D5185m		123	135	
Zinc	ppm	ASTM D5185m		26	26	
Sulfur	ppm	ASTM D5185m		1716	1508	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6	4	
Sodium	ppm	ASTM D5185m		7	10	
Potassium	ppm	ASTM D5185m	>20	1	<1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.06	0.093	



OIL ANALYSIS REPORT

VISUAL



	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Nov16/23	Appearance	scalar	*Visual	NORML	NORML	NORML	
Nov	Odor	scalar	*Visual	NORML	NORML	NORML	
°C	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	
	Free Water	scalar	*Visual		NEG	NEG	
	FLUID PROPERT	FIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		46.0	46.4	
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2
	Color				ASDruh EMAL Michael Mi		no image
	Bottom						no image
	GRAPHS						
	Ferrous Alloys						
	10 iron						
	6 - nickel						
u d	4-						
	2-						
				~			
	Aug28/23			Nov16/23			
	-			No			
	Non-ferrous Metal	s					
	8- copper						
E d	6 tin						
å.	4 -						
	2						
	0 23			123			
	Aug28/23			Nov16/23			
	Viscosity @ 40°C				Acid Number		
	55			₅ 0.10			
<u></u>	50 - Abnormal			(^B /HO) 0.08			1
cSt (40°C)	45			y 0.06 E 0.06 Mag 0.04 V 0.02 V 0.02 V 0.00	•		
	40 - Abnormal			10.04			
	35						
	Aug28/23			Nov16/23	Aug28/23		Nov16/23
	Aug			Nov	Aug		Nov1
Sample No. Lab Number Unique Number	: 06014107 : 10753251 : IND 2	Received Diagnose Diagnosti	:21 M d :24 M cian :Dou	Nov 2023 Nov 2023 Ig Bogart		CHAF	CKPORT PL RLOTTE, NC US 28273 OE KERLEY
* - Denotes test methods that are						T: (7	04)588-2299
Statements of conformity to specifi	cations are based on t	he simple .	acceptance c	lecision rule (ICGM 106:2012)		F:

Contact/Location: JOE KERLEY - UCLEWCHA