




# PROBLEM SUMMARY

## Sample Rating Trend




ISO



Machine Id  
**WEG**  
 Component  
**Coolant**  
 Fluid  
**NOT GIVEN (--- GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ASTM D7647	ABNORMAL	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>5000	▲ <b>8326</b>	1514	1955
Particles >6µm	ASTM D7647	>1300	▲ <b>4535</b>	825	1065
Particles >14µm	ASTM D7647	>160	▲ <b>772</b>	140	61
Particles >21µm	ASTM D7647	>40	▲ <b>260</b>	47	9
Particles >38µm	ASTM D7647	>10	▲ <b>40</b>	7	1
Particles >71µm	ASTM D7647	>3	▲ <b>4</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ <b>20/19/17</b>	18/17/14	18/17/13

Customer Id: UGIMESWC  
 Sample No.: WC0820270  
 Lab Number: 06014407  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

## HISTORICAL DIAGNOSIS

### 07 Sep 2023 Diag: Doug Bogart

NORMAL



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the coolant. The amount and size of particulates present in the system are acceptable. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits at 9.3.

[view report](#)



### 09 Aug 2022 Diag: Doug Bogart

NORMAL



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the coolant. The amount and size of particulates present in the system are acceptable. The glycol level is acceptable. The pH level of this fluid is within the acceptable limits at 9.4.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**WEG**  
 Component  
**Coolant**  
 Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Corrosion

All component wear rates are normal.

### Contaminants

There is a high amount of particulates present in the coolant.

### Coolant Condition

The glycol level is acceptable. The pH level of this fluid is within the acceptable limits at 9.4.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0820270</b>	WC0820277	WC0711738
Sample Date	Client Info		<b>14 Nov 2023</b>	07 Sep 2023	09 Aug 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130 >15	<b>0</b>	<1	0
Aluminum	ppm	ASTM D6130 >10	<b>0</b>	0	0
Lead	ppm	ASTM D6130 >10	<b>&lt;1</b>	0	0
Copper	ppm	ASTM D6130 >10	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D6130 >10	<b>1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D6130	<b>2</b>	7	5
Molybdenum	ppm	ASTM D6130	<b>3</b>	2	3
Magnesium	ppm	ASTM D6130	<b>2</b>	0	<1
Calcium	ppm	ASTM D6130	<b>2</b>	<1	<1
Phosphorus	ppm	ASTM D6130	<b>1671</b>	2920	1470
Zinc	ppm	ASTM D6130	<b>&lt;1</b>	0	0
Sulfur	ppm	ASTM D6130	<b>34</b>	21	20

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	<b>1</b>	2	6
Sodium	ppm	ASTM D6130	<b>125</b>	205	127
Potassium	ppm	ASTM D6130 >20	<b>5183</b>	8612	3028
Chlorine	ppm	ASTM D6130	<b>8</b>	8	4
Water	%	ASTM D6304	<b>47.9</b>	64.6	64.8
ppm Water	ppm	ASTM D6304	<b>479000</b>	646000	648000

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>▲ 8326</b>	1514	1955
Particles >6µm	ASTM D7647	>1300	<b>▲ 4535</b>	825	1065
Particles >14µm	ASTM D7647	>160	<b>▲ 772</b>	140	61
Particles >21µm	ASTM D7647	>40	<b>▲ 260</b>	47	9
Particles >38µm	ASTM D7647	>10	<b>▲ 40</b>	7	1
Particles >71µm	ASTM D7647	>3	<b>▲ 4</b>	1	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>▲ 20/19/17</b>	18/17/14	18/17/13

## VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual	<b>NEG</b>	NEG	NEG




# OIL ANALYSIS REPORT








FLUID PROPERTIES	method	limit/base	current	history1	history2
pH	Scale 0-14 ASTM D1287		<b>9.35</b>	9.31	9.42

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0820270 **Received** : 21 Nov 2023  
**Lab Number** : 06014407 **Diagnosed** : 07 Dec 2023  
**Unique Number** : 10753551 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, pH, PrtCount )

**UGI ENERGY SERVICES - LNG FACILITY**  
 80 ENERGY LN  
 MESHOPPEN, PA  
 US 18630  
 Contact: JOE BARRETT  
 jbarrett@ugies.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)