

PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY


070-COMPAIR-06 (S/N S287233)

Air Compressor

Fluid

NOT GIVEN (14 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status				ATTENTION	ATTENTION	NORMAL			
Visc @ 40°C	cSt	ASTM D445		△ 67.3	△ 63.9	54.2			

Customer Id: JACHUT Sample No.: USP245357 Lab Number: 06014548 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

17 Jul 2023 Diag: Doug Bogart

VISCOSITY



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid.



25 Jul 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



25 Apr 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

SAMPLE INFORMATION

VISCOSITY

070-COMPAIR-06 (S/N S287233)

Air Compressor

NOT GIVEN (14 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

▲ Fluid Condition

The oil viscosity is higher than normal. Confirmed. The AN level is acceptable for this fluid.

m2011 Jul2012	Jan2016	Jul2017	Jul2018	Jul2019	Jan 2021	Jan 2022	0c

Sample Number		Client Info		USP245357	USP245345	USP231485
Sample Date		Client Info		23 Oct 2023	17 Jul 2023	25 Jul 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1115	Client Info		N/A	N/A	N/A
Sample Status		Ciletit IIIIO		ATTENTION	ATTENTION	NORMAL
·				ATTENTION	ATTENTION	NORIVIAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>4	<1	0	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	2	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	<1	0	0
Tin	ppm	ASTM D5185m	>5	0	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		268	308	289
Zinc	ppm	ASTM D5185m		0	2	0
Sulfur	ppm	ASTM D5185m		348	470	348
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	0
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>0.6	0.010	0.002	0.002
ppm Water	ppm	ASTM D6304	>6000	104	23.8	20.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5619	1464	203
Particles >6µm		ASTM D7647	>2500	896	292	47
Particles >14µm		ASTM D7647	>320	21	13	9
Particles >21µm		ASTM D7647	>80	5	4	2
Particles >38µm		ASTM D7647	>20	0	1	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	20/17/12	18/15/11	15/13/10
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.13	0.11	0.078



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: 06014548 : 10753692 Test Package

: USP245357 Received : 21 Nov 2023 : 24 Nov 2023 Diagnosed

Diagnostician : Doug Bogart : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2600 E 4TH HUTCHINSON, KS US 67501

Contact: Jason Stanley

jason.stanley@kroger.com T: (620)694-6922

F: (620)663-5135