

# **OIL ANALYSIS REPORT**

# AREA II [500309040] Machine Id UNION P8031A (S/N PP-38-3)

Component

**Reciprocating Compressor** 

**ROYAL PURPLE SYNFILM 100 (2 GAL)** 





### DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.


# Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0810644	WC0804430	WC0758468
Sample Date		Client Info		09 Nov 2023	19 May 2023	01 Dec 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6	6	7
Chromium	ppm	ASTM D5185m	>10	<1	<1	0
Nickel	ppm	ASTM D5185m		<1	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	0	2
Lead	ppm	ASTM D5185m	>25	7	4	5
Copper	ppm	ASTM D5185m	>50	4	3	4
Tin	ppm	ASTM D5185m	>15	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	49	49	49
Calcium	ppm	ASTM D5185m		<1	8	2
Phosphorus	ppm	ASTM D5185m		5	8	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		20464	22104	20683
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		0	<1	<1
Potassium	ppm	ASTM D5185m	>20	2	<1	0
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.25	0.38	0.34	0.38



# **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FILLID DDODEDT						

FLUID PROPERTIES		method				history2	
Visc @ 40°C	cSt	ASTM D445	100	106	107	107	


SAMPLE IMAGES







Color


**Bottom** 







Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)







Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10753711

: WC0810644 : 06014567 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 21 Nov 2023 Diagnosed Diagnostician : Don Baldridge

: 24 Nov 2023

SI GROUP INC - ALBEMARLE 725 CANNON BRIDGE RD ORANGEBURG, SC

US 29115

Contact: ERIC PROVEAUX

eric.proveaux@contractors.siigroup.com T: (803)539-5228

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

F: (803)539-5426

Report Id: ALBORA [WUSCAR] 06014567 (Generated: 11/24/2023 14:20:13) Rev: 1