




PROBLEM SUMMARY

Sample Rating Trend



VIS DEBRIS



Machine Id
MYCOM SC-4 PRO-V NORTH (S/N 2210218)
 Component
Refrigeration Compressor
 Fluid
MYCOM MYCOLD AB68 (--- GAL)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

This is a baseline read-out on the submitted sample. FTIR matches baseline sample.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	NORMAL	NORMAL
Debris	scalar *Visual	▲ MODER	NONE	NONE

Customer Id: NORLEMNOR
Sample No.: USP242154
Lab Number: 06014686
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

08 Jun 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



08 Dec 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



09 Jun 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report






OIL ANALYSIS REPORT

Sample Rating Trend

VIS DEBRIS

Machine Id
MYCOM SC-4 PRO-V NORTH (S/N 2210218)
 Component
Refrigeration Compressor
 Fluid
MYCOM MYCOLD AB68 (--- GAL)



DIAGNOSIS

▲ Recommendation

This is a baseline read-out on the submitted sample. FTIR matches baseline sample.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		USP242154	USP250025	USP247422
Sample Date	Client Info		16 Nov 2023	08 Jun 2023	08 Dec 2022
Machine Age	hrs	Client Info	50324	46983	42956
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	NORMAL	NORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	---	0	0
Chromium	ppm	ASTM D5185m >2	---	0	0
Nickel	ppm	ASTM D5185m	---	0	0
Titanium	ppm	ASTM D5185m	---	0	0
Silver	ppm	ASTM D5185m >2	---	0	0
Aluminum	ppm	ASTM D5185m >3	---	0	0
Lead	ppm	ASTM D5185m >2	---	0	0
Copper	ppm	ASTM D5185m >8	---	0	0
Tin	ppm	ASTM D5185m >4	---	0	0
Vanadium	ppm	ASTM D5185m	---	0	0
Cadmium	ppm	ASTM D5185m	---	0	0




ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	---	0	0
Barium	ppm	ASTM D5185m	---	0	0
Molybdenum	ppm	ASTM D5185m	---	0	0
Manganese	ppm	ASTM D5185m	---	0	0
Magnesium	ppm	ASTM D5185m	---	0	0
Calcium	ppm	ASTM D5185m	---	0	0
Phosphorus	ppm	ASTM D5185m 2.3	---	0	0
Zinc	ppm	ASTM D5185m	---	0	0
Sulfur	ppm	ASTM D5185m 26	---	0	0

CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	---	4	<1
Sodium	ppm	ASTM D5185m	---	0	0
Potassium	ppm	ASTM D5185m >20	---	1	1
Water	%	ASTM D6304 >0.01	NEG	0.004	0.003
ppm Water	ppm	ASTM D6304 >100	---	44.5	37.9

INFRA-RED	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	---	---
Nitration	Abs/cm	*ASTM D7624	4.7	---	---
Sulfation	Abs/.1mm	*ASTM D7415	15.9	---	---



OIL ANALYSIS REPORT




FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		---	4875	2154
Particles >6µm	ASTM D7647	>2500	---	1218	563
Particles >14µm	ASTM D7647	>320	---	38	22
Particles >21µm	ASTM D7647	>80	---	8	5
Particles >38µm	ASTM D7647	>20	---	0	0
Particles >71µm	ASTM D7647	>4	---	0	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	---	19/17/12	18/16/12

FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414		6.6	---	---
Acid Number (AN)	mg KOH/g ASTM D974		---	0.014	0.015

VISUAL	method	limit/base	current	history1	history2
White Metal	scalar *Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar *Visual	NONE	NONE	NONE	NONE
Precipitate	scalar *Visual	NONE	NONE	NONE	NONE
Silt	scalar *Visual	NONE	NONE	NONE	NONE
Debris	scalar *Visual	NONE	▲ MODER	NONE	NONE
Sand/Dirt	scalar *Visual	NONE	NONE	NONE	NONE
Appearance	scalar *Visual	NORML	NORML	NORML	NORML
Odor	scalar *Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar *Visual	>0.01	NEG	NEG	NEG
Free Water	scalar *Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt ASTM D445	58.09	---	60.7	61.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USP242154 **Received** : 21 Nov 2023
Lab Number : **06014686** **Diagnosed** : 22 Nov 2023
Unique Number : 10753830 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: FT-IR)

NOR-AM COLD STORAGE - NORTH
 1555 21ST STEET
 LE MARS, IA
 US 51031
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (712)548-4663