

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


7917220 (S/N 1160)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

# **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL					
Particles >6µm	ASTM D7647	>1300	<u> </u>	1210					
Particles >14μm	ASTM D7647	>80	<b>165</b>	46					
Particles >21µm	ASTM D7647	>20	<u></u> 34	5					
Oil Cleanliness	ISO 4406 (c)	>17/13	<b>18/15</b>	17/13					

Customer Id: AMAAURDEN8
Sample No.: KCPA007277
Lab Number: 06015067
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 19 Sep 2022 Diag: Doug Bogart

NORMAL




No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# 7917220 (S/N 1160)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

# **DIAGNOSIS**

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Sep2022	Nov <sup>2</sup> 023		
				Nov2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA007277	KCP44482	
Sample Date		Client Info		10 Nov 2023	19 Sep 2022	
Machine Age	hrs	Client Info		3751	2167	
Oil Age	hrs	Client Info		0	2167	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper		ASTM D5185m		2	2	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium		ASTM D5185m	>10	0	0	
	ppm			•		
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	88	12	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	105	79	
Calcium	ppm	ASTM D5185m	0	4	2	
Phosphorus	ppm	ASTM D5185m	0	2	3	
Zinc	ppm	ASTM D5185m	0	0	1	
Sulfur	ppm	ASTM D5185m	23500	23003	21463	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	
Sodium	ppm	ASTM D5185m		20	10	
Potassium	ppm	ASTM D5185m	>20	5	3	
Water	%	ASTM D6304	>0.05	0.015	0.021	
ppm Water	ppm	ASTM D6304	>500	156	216.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		4021	4363	
Particles >6µm		ASTM D7647	>1300	<b>1555</b>	1210	
Particles >14μm		ASTM D7647	>80	<b>165</b>	46	
Particles >21µm		ASTM D7647	>20	<b>△</b> 34	5	
Particles >38μm		ASTM D7647	>4	0	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>17/13	<b>▲</b> 18/15	17/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.30	0.37	



# **OIL ANALYSIS REPORT**







Sample No. Lab Number **Unique Number** 

: KCPA007277

: 06015067 : 10754211

Received Diagnosed

: 22 Nov 2023 : 26 Nov 2023

Diagnostician : Don Baldridge

Contact: Service Manager

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

AURORA, CO

US 80018

T: F: