




# PROBLEM SUMMARY

Sample Rating Trend




Machine Id  
**8179962 (S/N 1358)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- QTS)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	Limit	ABNORMAL	ABNORMAL	NORMAL
Particles >6µm	ASTM D7647	>1300	▲ 1516	▲ 2782	674
Particles >14µm	ASTM D7647	>80	▲ 167	▲ 343	30
Particles >21µm	ASTM D7647	>20	▲ 54	▲ 76	6
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 19/18/15	▲ 20/19/16	17/12

Customer Id: READEN  
Sample No.: KCPA007117  
Lab Number: 06015074  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 13 Feb 2023 Diag: Don Baldrige

#### WEAR



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 11 Apr 2022 Diag: Doug Bogart

#### NORMAL




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Machine Id  
**8179962 (S/N 1358)**

Component

**Compressor**

Fluid

**KAESER SIGMA (OEM) M-460 (--- QTS)**

### DIAGNOSIS

#### ▲ Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### ▲ Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>KCPA007117</b>	KCP55385	KC103884
Sample Date	Client Info			<b>11 Nov 2023</b>	13 Feb 2023	11 Apr 2022
Machine Age	hrs	Client Info		<b>11203</b>	7401	2473
Oil Age	hrs	Client Info		<b>0</b>	4000	2473
Oil Changed	Client Info			<b>N/A</b>	Changed	Changed
Sample Status				<b>ABNORMAL</b>	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<b>0</b>	0	<1
Chromium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	>3	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	>3	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	>2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>2</b>	<1	<1
Lead	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m	>50	<b>30</b>	▲ 68	8
Tin	ppm	ASTM D5185m	>10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	90	<b>0</b>	2	38
Molybdenum	ppm	ASTM D5185m	0	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	100	<b>&lt;1</b>	<1	57
Calcium	ppm	ASTM D5185m	0	<b>0</b>	0	2
Phosphorus	ppm	ASTM D5185m	0	<b>&lt;1</b>	3	7
Zinc	ppm	ASTM D5185m	0	<b>0</b>	<1	8
Sulfur	ppm	ASTM D5185m	23500	<b>15631</b>	14691	15858

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	<1
Sodium	ppm	ASTM D5185m		<b>0</b>	0	15
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	12
Water	%	ASTM D6304	>0.05	<b>0.013</b>	0.005	0.005
ppm Water	ppm	ASTM D6304	>500	<b>138</b>	54.7	58.9

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>3968</b>	7174	4122
Particles >6µm		ASTM D7647	>1300	▲ <b>1516</b>	▲ 2782	674
Particles >14µm		ASTM D7647	>80	▲ <b>167</b>	▲ 343	30
Particles >21µm		ASTM D7647	>20	▲ <b>54</b>	▲ 76	6
Particles >38µm		ASTM D7647	>4	<b>2</b>	4	0
Particles >71µm		ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ <b>19/18/15</b>	▲ 20/19/16	17/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.42</b>	0.40	0.40


# OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	50.7	53.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA007117 **Received** : 22 Nov 2023  
**Lab Number** : 06015074 **Diagnosed** : 26 Nov 2023  
**Unique Number** : 10754218 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**READY FOODS INC**  
 2645 W 7TH AVE  
 DENVER, CO  
 US 80204  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)