




PROBLEM SUMMARY

Sample Rating Trend





WATER



Machine Id
KAESER AIR CENTER SM 7.5 6756186 (S/N 1045)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	ABNORMAL
Water	%	ASTM D6304	>0.05	▲ 0.252	0.004	▲ 0.220
ppm Water	ppm	ASTM D6304	>500	▲ 2520	43.5	▲ 2200
Particles >14µm		ASTM D7647	>80	▲ 191	17	▲ 392
Particles >21µm		ASTM D7647	>20	▲ 64	3	▲ 132
Particles >38µm		ASTM D7647	>4	▲ 10	0	▲ 20
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ 18/17/15	18/16/11	▲ 19/18/16

Customer Id: ZEV SOM
 Sample No.: KC101724
 Lab Number: 06015079
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

25 Apr 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Oct 2022 Diag: Doug Bogart

WATER



The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. Free water present. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



23 Sep 2021 Diag: Doug Bogart

WATER




We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition. The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Free water present. Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER AIR CENTER SM 7.5 6756186 (S/N 1045)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KC101724	KC112471	KC95986
Sample Date	Client Info	16 Oct 2023	25 Apr 2023	03 Oct 2022
Machine Age	hrs	21713	20220	18960
Oil Age	hrs	1500	2897	1623
Oil Changed	Client Info	Not Chngd	Changed	Not Chngd
Sample Status		ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	0	0	0
Chromium	ppm ASTM D5185m >10	<1	0	0
Nickel	ppm ASTM D5185m >3	<1	0	0
Titanium	ppm ASTM D5185m >3	<1	0	0
Silver	ppm ASTM D5185m >2	0	0	0
Aluminum	ppm ASTM D5185m >10	2	0	0
Lead	ppm ASTM D5185m >10	<1	0	0
Copper	ppm ASTM D5185m >50	2	6	6
Tin	ppm ASTM D5185m >10	0	0	0
Antimony	ppm ASTM D5185m	---	---	---
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	<1	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m 90	0	0	0
Molybdenum	ppm ASTM D5185m	<1	0	0
Manganese	ppm ASTM D5185m	<1	0	<1
Magnesium	ppm ASTM D5185m 90	18	7	9
Calcium	ppm ASTM D5185m 2	3	0	0
Phosphorus	ppm ASTM D5185m	3	2	2
Zinc	ppm ASTM D5185m	12	43	27

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	4	0	<1
Sodium	ppm ASTM D5185m	2	6	2
Potassium	ppm ASTM D5185m >20	2	1	0
Water	% ASTM D6304 >0.05	▲ 0.252	0.004	▲ 0.220
ppm Water	ppm ASTM D6304 >500	▲ 2520	43.5	▲ 2200






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	2062	1437	4224
Particles >6µm	ASTM D7647 >1300	1123	530	▲ 2301
Particles >14µm	ASTM D7647 >80	▲ 191	17	▲ 392
Particles >21µm	ASTM D7647 >20	▲ 64	3	▲ 132
Particles >38µm	ASTM D7647 >4	▲ 10	0	▲ 20
Particles >71µm	ASTM D7647 >3	1	0	▲ 2
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 18/17/15	18/16/11	▲ 19/18/16

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.4	0.31	0.21	0.29


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	▲ 2.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.7	43.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC101724 **Received** : 22 Nov 2023
Lab Number : 06015079 **Diagnosed** : 30 Nov 2023
Unique Number : 10754223 **Diagnostician** : Jonathan Hester
Test Package : IND 2

ZEVACOR
 110 CLYDE RD
 SOMERSET, NJ
 US 08873
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: