

PROBLEM SUMMARY

Sample Rating Trend




KAESER 7909270

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ATTENTION	ABNORMAL	ATTENTION			
Particles >14μm	ASTM D7647	>80	<u> </u>	<u>^</u> 218	78			
Particles >21μm	ASTM D7647	>20	△ 37	<u>^</u> 26	6			
Particles >38μm	ASTM D7647	>4	<u> </u>	1	0			
Oil Cleanliness	ISO 4406 (c)	>/17/13	19/17/14	21/20/15	20/18/13			

Customer Id: PARENG Sample No.: KC111033 Lab Number: 06015086 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

13 Apr 2023 Diag: Don Baldridge





Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



31 Aug 2022 Diag: Don Baldridge

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



ISO



KAESER 7909270

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug ² 022 Apr ² 023 Oc			23	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC111033	KC107031	KC99744
Sample Date		Client Info		20 Oct 2023	13 Apr 2023	31 Aug 2022
Machine Age	hrs	Client Info		6630	3718	1416
Oil Age	hrs	Client Info		2912	2301	1416
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ATTENTION	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	4	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	2	5
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	11	2
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	62	63	42
Calcium	ppm	ASTM D5185m	2	<1	1	<1
Phosphorus	ppm	ASTM D5185m		3	2	3
Zinc	ppm	ASTM D5185m		0	7	5
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	1	<1
Sodium	ppm	ASTM D5185m		18	18	8
Potassium	ppm	ASTM D5185m	>20	3	2	0
Water	%	ASTM D6304	>0.05	0.024	0.012	0.015
ppm Water	ppm	ASTM D6304	>500	242	120.8	155.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3898	13200	5863
Particles >6µm		ASTM D7647	>1300	1063	<u>▲</u> 5245	<u>▲</u> 1873
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>^</u> 218	78
Particles >21µm		ASTM D7647	>20	△ 37	<u>^</u> 26	6
Particles >38μm		ASTM D7647	>4	<u> </u>	1	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/14	△ 21/20/15	2 0/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.34	0.32	0.35



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: